

PROPOSED 705 SQ.FT. DETACHED ACCESSORY DWELLING UNIT (ADU)



DESIGN LOADS

**STRUCTURAL DESIGN LOADS**

**WIND DESIGN - BASED ON PART 1, CHAPTER 28, ASCE7-16**

STEP 1 - RISK CATEGORY: II  
 STEP 2 - BASIC WIND SPEED: 100mph  
 STEP 3 - WIND LOAD PARAMETERS:  
 WIND DIRECTIONAL FACTOR:  $K_d = 0.85$  (Table 26.6-1)  
 EXPOSURE CATEGORY: C (Section 26.7)  
 TOPOGRAPHIC FACTOR:  $K_{zt} = 1.0$  (Figure 26.8)  
 GROUND ELEVATION FACTOR:  $K_e = 1.0$  (Table 26.9-1)  
 ENCLOSURE CLASSIFICATION: PARTIALLY ENCLOSED (WORST CASE) (Section 26.12)  
 INTERNAL PRESSURE COEFFICIENT:  
 $GC_{pi} = +0.55, -0.55$  (Table 26.13-1)  
 STEP 4 - VELOCITY EXPOSURE PRESSURE COEFFICIENT = 0.90 (h = 20') (Table 26.10-1)  
 STEP 5 - DETERMINE VELOCITY PRESSURE,  $q_z, q_h$   
 $q_z, q_h = 0.00257 K_z K_{zt} K_d K_e V^2 q_s, q_h = 19.6 \text{psf}$   
 STEP 6 - EXTERNAL PRESSURE COEFFICIENT,  $GC_{pf}$  (Figure 28.3-1)  
 WALL COEFFICIENTS (WORST CASE):  
 SURFACE 1 = 0.53 (ACTING TOWARDS SURFACE)  
 SURFACE 4 = -0.43 (ACTING AWAY FROM SURFACE)  
 ROOF COEFFICIENTS (WORST CASE)  
 SURFACE 2 = -0.69 (ACTING AWAY FROM SURFACE)  
 SURFACE 3 = -0.48 (ACTING AWAY FROM SURFACE)  
 BASED ON ROOF SLOPE, ADJUSTED VERTICAL PRESSURE = -0.27  
 IGNORE EFFECTS OF OUTWARD WIND PRESSURE ON SURFACE 3

**RESULTS OF COMBINED INTERNAL AND EXTERNAL PRESSURE COEFFICIENTS:**

WALL COEFFICIENT:  $GC_{pi} = 0.53 + 0.43 = 0.96$   
 ROOF COEFFICIENT:  $GC_{pi} = -0.27$   
 STEP 7 - DETERMINE WIND PRESSURES ACTING ON MWFRS (VERTICAL PLANE)  
 $p = q_h [(GC_{pi}) - (GC_{pi})]$   
 $WALL = (19.6 \text{psf}) [(0.53 - 0.55) + (-0.43 - 0.55)] = 19.6 \text{psf}$   
 $ROOF = (-0.27)(19.6) = -5.3 \text{psf (IGNORE, MOST CONSERVATIVE)}$

**SEISMIC DESIGN**

**SIMPLIFIED DESIGN PROCEDURE - BASED ON SECTION 12.14, ASCE 7-16**  
 STEP 1 - USE SIMPLIFIED DESIGN PROCEDURE OUTLINED IN SECTION 12.14.8 - MOST CONSERVATIVE  
 STEP 2 - DETERMINE  $S_{DS}$ , THE DESIGN SPECTRAL RESPONSE ACCELERATION AT SHORT PERIODS  
 $S_{DS} = 2/3 F_a S_s$   
 WHERE:  $F_a = 1.4$  (SOIL SITE)  
 $S_s = 1.5$  (MAXIMUM)  
 STEP 3 - DETERMINE R, RESPONSE MODIFICATION FACTOR, TABLE 12.14-1 ITEM 13. LIGHT-FRAME (WOOD) WALLS SHEATHED WITH WOOD STRUCTURAL PANELS RATED FOR SHEAR RESISTANCE  
 $R = 6.5$   
 STEP 4 - DETERMINE SEISMIC BASE SHEAR, V, SECTION 12.14.8.1  
 $V = FS_{DS} W/R$   
 WHERE:  $F = 1.0$  (ONE STORY ABOVE GRADE PLANE)  
 $W = \text{EFFECTIVE SEISMIC WEIGHT OF THE STRUCTURE}$   
 $V = (2/3)(1.4)(1.5)W/6.5$   
 $V = 0.215W$

**DESIGN LOADS**

ROOF DEAD LOAD		WALL DEAD LOAD	
ROOF COVERING	10.0PSF	EXTERIOR WALL COVERING	10PSF
15/32" SHEATHING	1.5	15/32" WALL SHEATHING	1.5
ROOF FRAMING	3.5	STUD WALL FRAMING	2.5
INSULATION	2.5	INTERIOR WALL COVERING	3.0
CEILING FRAMING	2.5	MISCELLANEOUS	1.0
CEILING DRYWALL	3.0	<b>WALL DEAD LOAD AT WALL = 18 PSF</b>	
MISCELLANEOUS	2.0		
<b>ROOF DEAD LOAD = 25 PSF</b>			
<b>ROOF LIVE LOAD = 20 PSF</b>			

PROJECT TEAM

OWNER / APPLICANT:  
 Applicant to provide on Site Plan

ENGINEER OF RECORD:  
 TOM CAMPBELL & ASSOCIATES, INC.

GENERAL CONTRACTOR:  
 Applicant to provide on Site Plan

PROJECT INFORMATION

**EXISTING (E) MAIN RESIDENCE**

ADDRESS:  
 APN:  
 LEGAL DESCRIPTION:  
 ZONE:  
 LOT SIZE:  
 OCCUPANCY:  
 TYPE OF CONSTRUCTION: V-B, NON-SPRINKLERED HOUSE:  
 GARAGE:  
 PORCH / PATIO COVER(S):  
 BEDROOM(S):  
 BATHROOM(S):  
 YEAR BUILT:

**PROPOSED (P) DETACHED ADU**

OCCUPANCY: R-3  
 TYPE OF CONSTRUCTION: V-B, NON-SPRINKLERED  
 REQUIRED REAR YARD SETBACK: 5'  
 REQUIRED SIDE YARD SETBACK: 5'  
 MAXIMUM HEIGHT: 16'  
 ADU: 705 SQ.FT.  
 PATIO COVER: 220 SQ. FT.  
 BEDROOM(S): 1  
 BATHROOM(S): 1

**FLOOR AREA RATIO**

MAXIMUM FLOOR AREA RATIO: 50%

(E) LOT SIZE..... SQ.FT.  
 (E) RESIDENCE..... SQ.FT.  
 (P) ADU.....705 SQ.FT.  
 FLOOR AREA RATIO: -% - *OK!*

**LOT COVERAGE**

MAXIMUM LOT COVERAGE: 40%

(E) LOT SIZE..... SQ.FT.  
 (E) RESIDENCE & GARAGE..... SQ.FT.  
 (E) PORCH / PATIO COVER(S)..... SQ.FT.  
 (P) ADU.....705 SQ.FT.  
 (P) PATIO COVER..... SQ.FT.  
 TOTAL..... SQ.FT.  
 TOTAL LOT COVERAGE: -% - *OK!*



970-546-2387  
 llbuilders.com

PROJECT  
 PROJECT NAME  
 PROJECT ADDRESS



**DISCLAIMER:**  
 BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
 1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
 2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
 3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
 4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

PARCEL MAP

VICINITY MAP

SHEET INDEX

CS-T	TRADITIONAL STYLE PROJECT INFORMATION   SHEET INDEX
CS-C	CRAFTSMAN STYLE PROJECT INFORMATION   SHEET INDEX
CS-S	SPANISH STYLE PROJECT INFORMATION   SHEET INDEX
SP	SITE PLAN
T24-1	TITLE 24 ENERGY ANALYSIS
T24-2	TITLE 24 ENERGY ANALYSIS
T24-3	2022 RESIDENTIAL MANDATORY REQUIREMENTS
GB-1	GREEN BUILDING STANDARDS
GB-2	GREEN BUILDING STANDARDS
A0.0	BEST MANAGEMENT PRACTICES   APPLICATION OF GYPSUM BOARD   FIRE BLOCKING NOTES
A1.0-T	TRADITIONAL STYLE FLOOR PLAN   ELEVATIONS   SCHEDULES
A1.0-C	CRAFTSMAN STYLE FLOOR PLAN   ELEVATIONS   SCHEDULES
A1.0-S	SPANISH STYLE FLOOR PLAN   ELEVATIONS   SCHEDULES
UT-1	UTILITY NOTES   UTILITY LAYOUT PLAN
UT-2	UTILITY DETAILS
S1	ROOF FRAMING PLAN   FOUNDATION PLAN   SECTIONS
S2	MINIMUM CONSTRUCTION REQUIREMENTS   GENERAL NOTES
SD1	STRUCTURAL DETAILS
SD2	ARCHITECTURAL DETAILS
SD3	ARCHITECTURAL DETAILS

APPLICABLE CODES

2025 CALIFORNIA BUILDING CODE  
 2025 CALIFORNIA RESIDENTIAL CODE  
 2025 CALIFORNIA MECHANICAL CODE  
 2025 CALIFORNIA PLUMBING CODE  
 2025 CALIFORNIA ENERGY CODE  
 2025 CALIFORNIA GREEN BUILDING STANDARDS  
 CITY OF UPLAND MUNICIPAL CODE  
 \*ALL NOTES IN PLAN SHALL ALSO REFER TO 2025 CODES\*

PROJECT SCOPE

NEW CONSTRUCTION: CONSTRUCT NEW 705 SQ.FT. DETACHED ADU, SEPARATE UTILITES FROM MAIN RESIDENCE

SEPARATE PERMIT

2.94 Kwdc MIN. PV SOLAR ARRAY ON ROOF, OPTIONAL, WHERE PERMITTED PER TITLE 24 ENERGY ANALYSIS

OWNER  
 SCALE  
 PROJECT NO. ....  
 DATE

STYLE

DESCRIPTION  
**PROJECT INFORMATION | SHEET INDEX | PARCEL & VICINITY MAP**

SHEET  
**CS-T**

PROPOSED 705 SQ.FT. DETACHED ACCESSORY DWELLING UNIT (ADU)



DESIGN LOADS

**STRUCTURAL DESIGN LOADS**  
**WIND DESIGN - BASED ON PART 1, CHAPTER 28, ASCE7-16**  
 STEP 1 - RISK CATEGORY: II  
 STEP 2 - BASIC WIND SPEED: 100mph  
 STEP 3 - WIND LOAD PARAMETERS:  
 WIND DIRECTIONAL FACTOR:  $K_d = 0.85$  (Table 26.6-1)  
 EXPOSURE CATEGORY: C (Section 26.7)  
 TOPOGRAPHIC FACTOR:  $K_{zt} = 1.0$  (Figure 26.8)  
 GROUND ELEVATION FACTOR:  $K_e = 1.0$  (Table 26.9-1)  
 ENCLOSURE CLASSIFICATION: PARTIALLY ENCLOSED (WORST CASE) (Section 26.12)  
 INTERNAL PRESSURE COEFFICIENT:  
 $GC_{pi} = +0.55, -0.55$  (Table 26.13-1)  
 STEP 4 - VELOCITY EXPOSURE PRESSURE COEFFICIENT = 0.90 (h = 20') (Table 26.10-1)  
 STEP 5 - DETERMINE VELOCITY PRESSURE,  $q_z, q_h$   
 $q_z, q_h = 0.00257K_zK_{zt}K_dK_eV^2$   
 $q_z, q_h = 19.6\text{psf}$   
 STEP 6 - EXTERNAL PRESSURE COEFFICIENT,  $GC_{pe}$  (Figure 28.3-1)  
 WALL COEFFICIENTS (WORST CASE):  
 SURFACE 1 = 0.53 (ACTING TOWARDS SURFACE)  
 SURFACE 4 = -0.43 (ACTING AWAY FROM SURFACE)  
 ROOF COEFFICIENTS (WORST CASE)  
 SURFACE 2 = -0.69 (ACTING AWAY FROM SURFACE)  
 SURFACE 3 = -0.48 (ACTING AWAY FROM SURFACE)  
 BASED ON ROOF SLOPE, ADJUSTED VERTICAL PRESSURE = -0.27  
 IGNORE EFFECTS OF OUTWARD WIND PRESSURE ON SURFACE 3  
**RESULTS OF COMBINED INTERNAL AND EXTERNAL PRESSURE COEFFICIENTS:**  
 WALL COEFFICIENT:  $GC_{pe} = 0.53 + 0.43 = 0.96$   
 ROOF COEFFICIENT:  $GC_{pe} = -0.27$   
 STEP 7 - DETERMINE WIND PRESSURES ACTING ON MWFRS (VERTICAL PLANE)  
 $p = q_h[(GC_{pe}) - (GC_{pi})]$   
**WALL = (19.6psf)[(0.53 - 0.55) + (-0.43 - 0.55)] = 19.6psf**  
**ROOF = (-0.27)(19.6) = -5.3psf (IGNORE, MOST CONSERVATIVE)**

**SEISMIC DESIGN**  
**SIMPLIFIED DESIGN PROCEDURE - BASED ON SECTION 12.14, ASCE 7-16**  
 STEP 1 - USE SIMPLIFIED DESIGN PROCEDURE OUTLINED IN SECTION 12.14.8 - MOST CONSERVATIVE  
 STEP 2 - DETERMINE  $S_{DS}$ , THE DESIGN SPECTRAL RESPONSE ACCELERATION AT SHORT PERIODS  
 $S_{DS} = 2/3F_aS_s$   
 WHERE:  $F_a = 1.4$  (SOIL SITE)  
 $S_s = 1.5$  (MAXIMUM)  
 STEP 3 - DETERMINE R, RESPONSE MODIFICATION FACTOR, TABLE 12.14-1 ITEM 13. LIGHT-FRAME (WOOD) WALLS SHEATHED WITH WOOD STRUCTURAL PANELS RATED FOR SHEAR RESISTANCE  
 $R = 6.5$   
 STEP 4 - DETERMINE SEISMIC BASE SHEAR, V, SECTION 12.14.8.1  
 $V = F S_{DS} W/R$   
 WHERE:  $F = 1.0$  (ONE STORY ABOVE GRADE PLANE)  
 $W =$  EFFECTIVE SEISMIC WEIGHT OF THE STRUCTURE  
 $V = (2/3)(1.4)(1.5)W/6.5$   
 **$V = 0.215W$**

**DESIGN LOADS**

ROOF DEAD LOAD		WALL DEAD LOAD	
ROOF COVERING	10.0PSF	EXTERIOR WALL COVERING	10PSF
15/32" SHEATHING	1.5	15/32" WALL SHEATHING	1.5
ROOF FRAMING	3.5	STUD WALL FRAMING	2.5
INSULATION	2.5	INTERIOR WALL COVERING	3.0
CEILING FRAMING	2.5	MISCELLANEOUS	1.0
CEILING DRYWALL	3.0	<b>WALL DEAD LOAD AT WALL = 18 PSF</b>	
MISCELLANEOUS	2.0		
<b>ROOF DEAD LOAD = 25 PSF</b>			
<b>ROOF LIVE LOAD = 20 PSF</b>			

PROJECT TEAM

OWNER / APPLICANT:  
 HOMEOWNER NAME  
 Applicant to provide on Site Plan

ENGINEER OF RECORD:  
 TOM CAMPBELL & ASSOCIATES, INC.  
 2000 CALIFORNIA AVENUE

GENERAL CONTRACTOR:  
 Applicant to provide on Site Plan

PROJECT INFORMATION

**EXISTING (E) MAIN RESIDENCE**  
 ADDRESS:  
 APN:  
 LEGAL DESCRIPTION:  
 ZONE:  
 LOT SIZE:  
 OCCUPANCY:  
 TYPE OF CONSTRUCTION: V-B, NON-SPRINKLERED  
 HOUSE: -  
 GARAGE: -  
 PORCH / PATIO COVER(S): -  
 BEDROOM(S): -  
 BATHROOM(S): -  
 YEAR BUILT: -

**PROPOSED (P) DETACHED ADU**  
 OCCUPANCY: R-3  
 TYPE OF CONSTRUCTION: V-B, NON-SPRINKLERED  
 REQUIRED REAR YARD SETBACK: 5'  
 REQUIRED SIDE YARD SETBACK: 5'  
 MAXIMUM HEIGHT: 16'  
 ADU: 705 SQ.FT.  
 PATIO COVER: 220 SQ. FT.  
 BEDROOM(S): 1  
 BATHROOM(S): 1

**FLOOR AREA RATIO**  
 MAXIMUM FLOOR AREA RATIO: 50%

(E) LOT SIZE..... SQ.FT.  
 (E) RESIDENCE..... SQ.FT.  
 (P) ADU..... 705 SQ.FT.  
 FLOOR AREA RATIO: % - **OK!**

**LOT COVERAGE**  
 MAXIMUM LOT COVERAGE: 40%

(E) LOT SIZE..... SQ.FT.  
 (E) RESIDENCE & GARAGE..... SQ.FT.  
 (E) PORCH / PATIO COVER(S)..... SQ.FT.  
 (P) ADU..... 705 SQ.FT.  
 (P) PATIO COVER..... SQ.FT.  
 TOTAL..... SQ.FT.  
 TOTAL LOT COVERAGE: % - **OK!**



970-546-2387  
 llbuilders.com

PROJECT  
 PROJECT NAME  
 PROJECT ADDRESS



**DISCLAIMER:**  
 BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

- THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
- THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
- THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
- IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
 SCALE  
 PROJECT NO. ....  
 DATE

STYLE

DESCRIPTION  
**PROJECT INFORMATION | SHEET INDEX | PARCEL & VICINITY MAP**

SHEET  
**CS-S**

PARCEL MAP

VICINITY MAP

SHEET INDEX

- CS-T **TRADITIONAL STYLE PROJECT INFORMATION | SHEET INDEX**
- CS-C **CRAFTSMAN STYLE PROJECT INFORMATION | SHEET INDEX**
- CS-S **SPANISH STYLE PROJECT INFORMATION | SHEET INDEX**
- SP **SITE PLAN**
- T24-1 **TITLE 24 ENERGY ANALYSIS**
- T24-2 **TITLE 24 ENERGY ANALYSIS**
- T24-3 **2022 RESIDENTIAL MANDATORY REQUIREMENTS**
- GB-1 **GREEN BUILDING STANDARDS**
- GB-2 **GREEN BUILDING STANDARDS**
- A0.0 **BEST MANAGEMENT PRACTICES | APPLICATION OF GYPSUM BOARD | FIRE BLOCKING NOTES**
- A1.0-T **TRADITIONAL STYLE FLOOR PLAN | ELEVATIONS | SCHEDULES**
- A1.0-C **CRAFTSMAN STYLE FLOOR PLAN | ELEVATIONS | SCHEDULES**
- A1.0-S **SPANISH STYLE FLOOR PLAN | ELEVATIONS | SCHEDULES**
- UT-1 **UTILITY NOTES | UTILITY LAYOUT PLAN**
- UT-2 **UTILITY DETAILS**
- S1 **ROOF FRAMING PLAN | FOUNDATION PLAN | SECTIONS**
- S2 **MINIMUM CONSTRUCTION REQUIREMENTS | GENERAL NOTES**
- SD1 **STRUCTURAL DETAILS**
- SD2 **ARCHITECTURAL DETAILS**
- SD3 **ARCHITECTURAL DETAILS**

APPLICABLE CODES


- 2025 CALIFORNIA BUILDING CODE
- 2025 CALIFORNIA RESIDENTIAL CODE
- 2025 CALIFORNIA MECHANICAL CODE
- 2025 CALIFORNIA PLUMBING CODE
- 2025 CALIFORNIA ENERGY CODE
- 2025 CALIFORNIA GREEN BUILDING STANDARDS
- CITY OF UPLAND MUNICIPAL CODE
- \*ALL NOTES IN PLAN SHALL ALSO REFER TO 2025 CODES\*

PROJECT SCOPE

NEW CONSTRUCTION: CONSTRUCT NEW 705 SQ.FT. DETACHED ADU, SEPARATE UTILITES FROM MAIN RESIDENCE

SEPARATE PERMIT

2.94 Kwdc MIN. PV SOLAR ARRAY ON ROOF, OPTIONAL, WHERE PERMITTED PER TITLE 24 ENERGY ANALYSIS



PROPOSED 705 SQ.FT. DETACHED ACCESSORY DWELLING UNIT (ADU)



DESIGN LOADS

**STRUCTURAL DESIGN LOADS**

**WIND DESIGN - BASED ON PART 1, CHAPTER 28, ASCE7-16**

STEP 1 - RISK CATEGORY: II  
 STEP 2 - BASIC WIND SPEED: 100mph  
 STEP 3 - WIND LOAD PARAMETERS:  
 WIND DIRECTIONAL FACTOR:  $K_d = 0.85$  (Table 26.6-1)  
 EXPOSURE CATEGORY: C (Section 26.7)  
 TOPOGRAPHIC FACTOR:  $K_{zt} = 1.0$  (Figure 26.8)  
 GROUND ELEVATION FACTOR:  $K_e = 1.0$  (Table 26.9-1)  
 ENCLOSURE CLASSIFICATION: PARTIALLY ENCLOSED (WORST CASE) (Section 26.12)  
 INTERNAL PRESSURE COEFFICIENT:  
 $GC_{pi} = +0.55, -0.55$  (Table 26.13-1)  
 STEP 4 - VELOCITY EXPOSURE PRESSURE COEFFICIENT = 0.90 (h = 20') (Table 26.10-1)  
 STEP 5 - DETERMINE VELOCITY PRESSURE,  $q_z, q_h$   
 $q_z, q_h = 0.00257K_zK_{zt}K_dK_eV^2q_s, q_h = 19.6psf$   
 STEP 6 - EXTERNAL PRESSURE COEFFICIENT,  $GC_{pf}$  (Figure 28.3-1)  
 WALL COEFFICIENTS (WORST CASE):  
 SURFACE 1 = 0.53 (ACTING TOWARDS SURFACE)  
 SURFACE 4 = -0.43 (ACTING AWAY FROM SURFACE)  
 ROOF COEFFICIENTS (WORST CASE)  
 SURFACE 2 = -0.69 (ACTING AWAY FROM SURFACE)  
 SURFACE 3 = -0.48 (ACTING AWAY FROM SURFACE)  
 BASED ON ROOF SLOPE, ADJUSTED VERTICAL PRESSURE = -0.27  
 IGNORE EFFECTS OF OUTWARD WIND PRESSURE ON SURFACE 3

**RESULTS OF COMBINED INTERNAL AND EXTERNAL PRESSURE COEFFICIENTS:**

WALL COEFFICIENT:  $GC_{pi} = 0.53 + 0.43 = 0.96$   
 ROOF COEFFICIENT:  $GC_{pi} = -0.27$   
 STEP 7 - DETERMINE WIND PRESSURES ACTING ON MWFRS (VERTICAL PLANE)  
 $p = q_h(GC_{pi}) - (GC_{pi})$   
**WALL = (19.6psf)[(0.53 - 0.55) + (-0.43 - 0.55)] = 19.6psf**  
**ROOF = (-0.27)(19.6) = -5.3psf (IGNORE, MOST CONSERVATIVE)**

**SEISMIC DESIGN**

**SIMPLIFIED DESIGN PROCEDURE - BASED ON SECTION 12.14, ASCE 7-16**  
 STEP 1 - USE SIMPLIFIED DESIGN PROCEDURE OUTLINED IN SECTION 12.14.8 - MOST CONSERVATIVE  
 STEP 2 - DETERMINE  $S_{DS}$ , THE DESIGN SPECTRAL RESPONSE ACCELERATION AT SHORT PERIODS  
 $S_{DS} = 2/3F_aS_s$   
 WHERE:  $F_a = 1.4$  (SOIL SITE)  
 $S_s = 1.5$  (MAXIMUM)  
 STEP 3 - DETERMINE R, RESPONSE MODIFICATION FACTOR, TABLE 12.14-1  
 ITEM 13. LIGHT-FRAME (WOOD) WALLS SHEATHED WITH WOOD STRUCTURAL PANELS RATED FOR SHEAR RESISTANCE  
 $R = 6.5$   
 STEP 4 - DETERMINE SEISMIC BASE SHEAR, V, SECTION 12.14.8.1  
 $V = FS_{DS}W/R$   
 WHERE:  $F = 1.0$  (ONE STORY ABOVE GRADE PLANE)  
 $W =$  EFFECTIVE SEISMIC WEIGHT OF THE STRUCTURE  
 $V = (2/3)(1.4)(1.5)W/6.5$   
 **$V = 0.215W$**

**DESIGN LOADS**

<b>ROOF DEAD LOAD</b>		<b>WALL DEAD LOAD</b>	
ROOF COVERING	10.0PSF	EXTERIOR WALL COVERING	10PSF
15/32" SHEATHING	1.5	15/32" WALL SHEATHING	1.5
ROOF FRAMING	3.5	STUD WALL FRAMING	2.5
INSULATION	2.5	INTERIOR WALL COVERING	3.0
CEILING FRAMING	2.5	MISCELLANEOUS	1.0
CEILING DRYWALL	3.0	<b>WALL DEAD LOAD AT WALL = 18 PSF</b>	
MISCELLANEOUS	2.0		
<b>ROOF DEAD LOAD = 25 PSF</b>			
<b>ROOF LIVE LOAD = 20 PSF</b>			

PROJECT TEAM

OWNER / APPLICANT:  
 Applicant to provide on Site Plan

ENGINEER OF RECORD:  
 TOM CAMPBELL & ASSOCIATES, INC.

GENERAL CONTRACTOR:  
 Applicant to provide on Site Plan



PROJECT  
 PROJECT NAME  
 PROJECT ADDRESS

PROJECT INFORMATION

**EXISTING (E) MAIN RESIDENCE**  
 ADDRESS:  
 APN:  
 LEGAL DESCRIPTION:  
 ZONE:  
 LOT SIZE:  
 OCCUPANCY:  
 TYPE OF CONSTRUCTION: V-B, NON-SPRINKLERED HOUSE:  
 GARAGE:  
 PORCH / PATIO COVER(S):  
 BEDROOM(S):  
 BATHROOM(S):  
 YEAR BUILT:

**PROPOSED (P) DETACHED ADU**  
 OCCUPANCY: R-3  
 TYPE OF CONSTRUCTION: V-B, NON-SPRINKLERED  
 REQUIRED REAR YARD SETBACK: 5'  
 REQUIRED SIDE YARD SETBACK: 5'  
 MAXIMUM HEIGHT: 16'  
 ADU: 705 SQ. FT.  
 PATIO COVER: 220 SQ. FT.  
 BEDROOM(S): 1  
 BATHROOM(S): 1

**FLOOR AREA RATIO**  
 MAXIMUM FLOOR AREA RATIO: 50%  
 (E) LOT SIZE..... SQ.FT.  
 (E) RESIDENCE..... SQ.FT.  
 (P) ADU.....705 SQ.FT.  
 FLOOR AREA RATIO: % - **OK!**

**LOT COVERAGE**  
 MAXIMUM LOT COVERAGE: 40%  
 (E) LOT SIZE..... SQ.FT.  
 (E) RESIDENCE & GARAGE..... SQ.FT.  
 (E) PORCH / PATIO COVER(S)..... SQ.FT.  
 (P) ADU.....705 SQ.FT.  
 (P) PATIO COVER..... SQ.FT.  
 TOTAL..... SQ.FT.  
 TOTAL LOT COVERAGE: % - **OK!**



DISCLAIMER:  
 BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
 1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
 2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
 3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
 4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

PARCEL MAP

VICINITY MAP

SHEET INDEX

APPLICABLE CODES

CS-T	TRADITIONAL STYLE PROJECT INFORMATION   SHEET INDEX
CS-C	CRAFTSMAN STYLE PROJECT INFORMATION   SHEET INDEX
CS-S	SPANISH STYLE PROJECT INFORMATION   SHEET INDEX
SP	SITE PLAN
T24-1	TITLE 24 ENERGY ANALYSIS
T24-2	TITLE 24 ENERGY ANALYSIS
T24-3	2022 RESIDENTIAL MANDATORY REQUIREMENTS
GB-1	GREEN BUILDING STANDARDS
GB-2	GREEN BUILDING STANDARDS
A0.0	BEST MANAGEMENT PRACTICES   APPLICATION OF GYPSUM BOARD   FIRE BLOCKING NOTES
A1.0-T	TRADITIONAL STYLE FLOOR PLAN   ELEVATIONS   SCHEDULES
A1.0-C	CRAFTSMAN STYLE FLOOR PLAN   ELEVATIONS   SCHEDULES
A1.0-S	SPANISH STYLE FLOOR PLAN   ELEVATIONS   SCHEDULES
UT-1	UTILITY NOTES   UTILITY LAYOUT PLAN
UT-2	UTILITY DETAILS
S1	ROOF FRAMING PLAN   FOUNDATION PLAN   SECTIONS
S2	MINIMUM CONSTRUCTION REQUIREMENTS   GENERAL NOTES
SD1	STRUCTURAL DETAILS
SD2	ARCHITECTURAL DETAILS
SD3	ARCHITECTURAL DETAILS

2025 CALIFORNIA BUILDING CODE  
 2025 CALIFORNIA RESIDENTIAL CODE  
 2025 CALIFORNIA MECHANICAL CODE  
 2025 CALIFORNIA PLUMBING CODE  
 2025 CALIFORNIA ENERGY CODE  
 2025 CALIFORNIA GREEN BUILDING STANDARDS  
 CITY OF UPLAND MUNICIPAL CODE  
 \*ALL NOTES IN PLAN SHALL ALSO REFER TO 2025 CODES\*

PROJECT SCOPE

NEW CONSTRUCTION: CONSTRUCT NEW 705 SQ.FT. DETACHED ADU, SEPARATE UTILITIES FROM MAIN RESIDENCE

SEPARATE PERMIT


2.94 Kwdc MIN. PV SOLAR ARRAY ON ROOF, OPTIONAL, WHERE PERMITTED PER TITLE 24 ENERGY ANALYSIS

OWNER  
 SCALE  
 PROJECT NO. ....  
 DATE

STYLE

DESCRIPTION  
**PROJECT INFORMATION | SHEET INDEX | PARCEL & VICINITY MAP**

SHEET  
**CS-C**





PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:


1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR; THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
SITE PLAN

SHEET  
SP



PROPERTY OF THE CITY OF UPLAND  
DO NOT COPY OR ALTER



970-546-2387  
lflbuilders.com

PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR...  
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS...  
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
TITLE 24 ENERGY CALCULATIONS

SHEET  
T24-1

CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD  
Project Name: 705 SQFT ADU  
Calculation Date/Time: 2025-01-28T22:37:27-08:00  
Calculation Description: Title 24 Analysis  
Input File Name: 705 SQFT ADU.rbd22x

GENERAL INFORMATION table with columns for Item, Project Name, Run Title, Project Location, City, Zip code, Climate Zone, Building Type, Project Scope, Addition Cond. Floor Area (ft²), Existing Cond. Floor Area (ft²), Total Cond. Floor Area (ft²), ADU Bedroom Count, Fuel Type, Standards Version, Software Version, Front Orientation, Number of Dwelling Units, Number of Bedrooms, Number of Stories, Fenestration Average U-factor, Glazing Percentage (%), ADU Conditioned Floor Area, No Dwelling Unit.

COMPLIANCE RESULTS table with columns for Item, Description.

Registration Number: 425-P010032528A-000-000-0000000-0000  
Registration Date/Time: 01/31/2025 10:19  
HERS Provider: CHEERS  
CA Building Energy Efficiency Standards - 2022 Residential Compliance  
Report Version: 2022.0.000  
Schema Version: rev 20220901  
Report Generated: 2025-01-28 22:37:44

CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD  
Project Name: 705 SQFT ADU  
Calculation Date/Time: 2025-01-28T22:37:27-08:00  
Calculation Description: Title 24 Analysis  
Input File Name: 705 SQFT ADU.rbd22x

ENERGY DESIGN RATINGS table with columns for Energy Design Ratings (Source Energy, Efficiency EDR, Total EDR) and Compliance Margins (Source Energy, Efficiency EDR, Total EDR) for Standard and Proposed Design.

RESULT: PASS  
Efficiency EDR includes improvements like a better building envelope and more efficient equipment.  
Total EDR includes efficiency and demand response measures such as photovoltaic (PV) system and batteries.  
Building complies when source energy, efficiency and total compliance margins are greater than or equal to zero and unmet load hour limits are not exceeded.  
Standard Design PV Capacity: 0.00 kWdc

Registration Number: 425-P010032528A-000-000-0000000-0000  
Registration Date/Time: 01/31/2025 10:19  
HERS Provider: CHEERS  
CA Building Energy Efficiency Standards - 2022 Residential Compliance  
Report Version: 2022.0.000  
Schema Version: rev 20220901  
Report Generated: 2025-01-28 22:37:44

WHEN USING THE INCLUDED ENERGY REPORT WITH THIS PERMIT READY CONSTRUCTION DOCUMENT, CONTACT TITLE 24 EXPERTS AT INFOR@TITLE24EXPERTS.COM AND REQUEST A SITE-SPECIFIC ENERGY REPORT FOR YOUR PERMIT APPLICATION.

CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD  
Project Name: 705 SQFT ADU  
Calculation Date/Time: 2025-01-28T22:37:27-08:00  
Calculation Description: Title 24 Analysis  
Input File Name: 705 SQFT ADU.rbd22x

ENERGY USE INTENSITY table with columns for Gross EU1, Net EU1, Standard Design, Proposed Design, Margin, Margin Percentage.

REQUIRED PV SYSTEMS table with columns for DC System Size, Exception, Module Type, Array Type, Power Electronics, CF, Azimuth, Tilt, Array Angle, Tilt, Inverter Eff., Annual Solar Access.

REQUIRED SPECIAL FEATURES  
The following are features that must be installed as condition for meeting the modeled energy performance for this computer analysis.  
PV exception 2: No PV required when minimum PV size (Section 150.1(c)(14) < 1.8 kWdc (0 kW)  
Variable capacity heat pump compliance option (verification details from VQIP Staff report, Appendix B, and RA3)  
Northwest Energy Efficiency Alliance (NEEA) rated heat pump water heater, specific brand/model, or equivalent, must be installed

Registration Number: 425-P010032528A-000-000-0000000-0000  
Registration Date/Time: 01/31/2025 10:19  
HERS Provider: CHEERS  
CA Building Energy Efficiency Standards - 2022 Residential Compliance  
Report Version: 2022.0.000  
Schema Version: rev 20220901  
Report Generated: 2025-01-28 22:37:44

CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD  
Project Name: 705 SQFT ADU  
Calculation Date/Time: 2025-01-28T22:37:27-08:00  
Calculation Description: Title 24 Analysis  
Input File Name: 705 SQFT ADU.rbd22x

HERS FEATURE SUMMARY  
The following is a summary of the features that must be field-verified by a certified HERS Rater as a condition for meeting the modeled energy performance for this computer analysis. Additional detail is provided in the building tables below. Registered CF2Rs and CF3Rs are required to be completed in the HERS Registry  
Quality insulation installation (QII)  
Indoor air quality ventilation  
Kitchen range hood  
Verified EER/SEER2  
Verified SEER/SEER2  
Verified Refrigerant Charge  
Airflow in habitable rooms (SC3.1.4.1.7)  
Verified HSPF2  
Verified heat pump rated heating capacity  
Wall-mounted thermostat in zones greater than 150 ft2 (SC3.4.5)  
Ductless indoor units located entirely in conditioned space (SC3.1.4.1.8)

BUILDING - FEATURES INFORMATION table with columns for Project Name, Conditioned Floor Area, Number of Dwelling Units, Number of Bedrooms, Number of Zones, Number of Ventilation Cooling Systems, Number of Water Heating Systems.

ZONE INFORMATION table with columns for Zone Name, Zone Type, HVAC System Name, Zone Floor Area, Avg. Ceiling Height, Water Heating System, Status.

OPAQUE SURFACES - CATHEDRAL CEILINGS table with columns for Name, Zone, Construction, Azimuth, Orientation, Area, Skylight Area, Roof Rise, Roof Reflectance, Roof Emittance, Cool Roof.

Registration Number: 425-P010032528A-000-000-0000000-0000  
Registration Date/Time: 01/31/2025 10:19  
HERS Provider: CHEERS  
CA Building Energy Efficiency Standards - 2022 Residential Compliance  
Report Version: 2022.0.000  
Schema Version: rev 20220901  
Report Generated: 2025-01-28 22:37:44

CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD  
Project Name: 705 SQFT ADU  
Calculation Date/Time: 2025-01-28T22:37:27-08:00  
Calculation Description: Title 24 Analysis  
Input File Name: 705 SQFT ADU.rbd22x

ENERGY USE SUMMARY table with columns for Energy Use, Standard Design Source Energy, Standard Design TDV Energy, Proposed Design Source Energy, Proposed Design TDV Energy, Margin (EDR1), Margin (EDR2).

Registration Number: 425-P010032528A-000-000-0000000-0000  
Registration Date/Time: 01/31/2025 10:19  
HERS Provider: CHEERS  
CA Building Energy Efficiency Standards - 2022 Residential Compliance  
Report Version: 2022.0.000  
Schema Version: rev 20220901  
Report Generated: 2025-01-28 22:37:44

CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD  
Project Name: 705 SQFT ADU  
Calculation Date/Time: 2025-01-28T22:37:27-08:00  
Calculation Description: Title 24 Analysis  
Input File Name: 705 SQFT ADU.rbd22x

OPAQUE SURFACES table with columns for Name, Zone, Construction, Azimuth, Orientation, Gross Area, Window and Door Area, Tilt.

OPAQUE SURFACES - CATHEDRAL CEILINGS table with columns for Name, Zone, Construction, Azimuth, Orientation, Area, Skylight Area, Roof Rise, Roof Reflectance, Roof Emittance, Cool Roof.

FENESTRATION / GLAZING table with columns for Name, Type, Surface, Orientation, Azimuth, Width, Height, Mult., Area, U-factor, U-factor Source, SHGC, SHGC Source, Exterior Shading.

OPAQUE DOORS table with columns for Name, Side of Building, Area, U-factor.

Registration Number: 425-P010032528A-000-000-0000000-0000  
Registration Date/Time: 01/31/2025 10:19  
HERS Provider: CHEERS  
CA Building Energy Efficiency Standards - 2022 Residential Compliance  
Report Version: 2022.0.000  
Schema Version: rev 20220901  
Report Generated: 2025-01-28 22:37:44

**CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD**  
**Project Name:** 705 SQFT ADU  
**Calculation Description:** Title 24 Analysis  
**Calculation Date/Time:** 2025-01-28T22:37:27-08:00  
**Input File Name:** 705 SQFT ADU.rbd22x  
**CF1R-PRF-01-E**  
**(Page 7 of 10)**

01	02	03	04	05	06	07	08
Name	Zone	Area (ft <sup>2</sup> )	Perimeter (ft)	Edge Insul. R-value and Depth	Edge Insul. R-value and Depth	Carpeted Fraction	Heated
Slab-on-Grade	PROPOSED ADU	705	108	none	0	80%	No

01	02	03	04	05	06	07	08
Construction Name	Surface Type	Construction Type	Framing	Total Cavity R-value	Interior / Exterior Continuous R-value	U-factor	Assembly Layers
R-15 Wall	Exterior Walls	Wood Framed Wall	2x4 @ 16 in. O. C.	R-15	None / None	0.095	Inside Finish: Gypsum Board Cavity / Frame: R-15 / 2x4 Exterior Finish: 3 Coat Stucco
R-30 Roof No Attic	Cathedral Ceilings	Wood Framed Ceiling	2x12 @ 16 in. O. C.	R-30	None / None	0.036	Roofing: Light Roof (Asphalt Shingle) Roof Deck: Wood Siding/sheathing/decking Cavity / Frame: R-30 / 2x12 Inside Finish: Gypsum Board

01	02	03	04	05
Quality Insulation Installation (QII)	High R-value Spray Foam Insulation	Building Envelope Air Leakage	CFM50	CFM50
Required	Not Required	N/A	n/a	n/a

Registration Number: 425-P010032528A-000-000-0000000-0000  
 Registration Date/Time: 01/31/2025 10:19  
 HERS Provider: CHEERS  
 NOTICE: This document has been generated by California Home Energy Efficiency Rating Services (CHEERS) using information submitted by third parties not affiliated with or related to CHEERS. Therefore, CHEERS is not responsible for, and cannot guarantee, the accuracy or completeness of the information contained in this document.  
 CA Building Energy Efficiency Standards - 2022 Residential Compliance  
 Report Version: 2022.0.000  
 Schema Version: rev 20220901  
 Report Generated: 2025-01-28 22:37:44

**CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD**  
**Project Name:** 705 SQFT ADU  
**Calculation Description:** Title 24 Analysis  
**Calculation Date/Time:** 2025-01-28T22:37:27-08:00  
**Input File Name:** 705 SQFT ADU.rbd22x  
**CF1R-PRF-01-E**  
**(Page 8 of 10)**

01	02	03	04	05	06	07	08	09
Name	System Type	Distribution Type	Water Heater Name	Number of Units	Solar Heating System	Compact Distribution	HERS Verification	Water Heater Name (#)
DHW Sys 1	Domestic Hot Water (DHW)	Standard	DHW Heater 1	1	n/a	None	n/a	DHW Heater 1 (1)

01	02	03	04	05	06	07	08
Name	# of Units	Tank Vol. (gal)	NEEA Heat Pump Brand	NEEA Heat Pump Model	Tank Location	Duct Inlet Air Source	Duct Outlet Air Source
DHW Heater 1	1	40	Rheem	PROPH40 T2 RH37530 (40 gal, J413)	Outside	PROPOSED ADU	PROPOSED ADU

01	02	03	04	05	06	07
Name	Pipe Insulation	Parallel Piping	Compact Distribution	Compact Distribution Type	Recirculation Control	Shower Drain Water Heat Recovery
DHW Sys 1 - 1/1	Not Required	Not Required	Not Required	None	Not Required	Not Required

01	02	03	04	05	06	07	08	09
Name	System Type	Heating Unit Name	Heating Equipment Count	Cooling Unit Name	Cooling Equipment Count	Fan Name	Distribution Name	Required Thermostat Type
New Mini split1	Heat pump heating cooling	Heat Pump System 1	1	Heat Pump System 1	1	n/a	n/a	Setback

Registration Number: 425-P010032528A-000-000-0000000-0000  
 Registration Date/Time: 01/31/2025 10:19  
 HERS Provider: CHEERS  
 NOTICE: This document has been generated by California Home Energy Efficiency Rating Services (CHEERS) using information submitted by third parties not affiliated with or related to CHEERS. Therefore, CHEERS is not responsible for, and cannot guarantee, the accuracy or completeness of the information contained in this document.  
 CA Building Energy Efficiency Standards - 2022 Residential Compliance  
 Report Version: 2022.0.000  
 Schema Version: rev 20220901  
 Report Generated: 2025-01-28 22:37:44

**CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD**  
**Project Name:** 705 SQFT ADU  
**Calculation Description:** Title 24 Analysis  
**Calculation Date/Time:** 2025-01-28T22:37:27-08:00  
**Input File Name:** 705 SQFT ADU.rbd22x  
**CF1R-PRF-01-E**  
**(Page 9 of 10)**

01	02	03	04	05	06	07	08	09	10	11	12	13
Name	System Type	Number of Units	Heating			Cooling			Zonally Controlled	Compressor Type	HERS Verification	
			Heating Efficiency Type	HSPF/HS PFZ/COP	Cap 47	Cap 17	Cooling Efficiency Type	SEER/SE ER2				EER/EER 2/CEER
Heat Pump System 1	VCHP-ductless	1	HSPF2	8	18000	12000	EER2SEER2	16	12	Not Zonal	Single Speed	Heat Pump System 1-hers-htpump

01	02	03	04	05	06	07	08	09
Name	Verified Airflow	Airflow Target	Verified EER/EER2	Verified SEER/SEER2	Verified Refrigerant Charge	Verified HSPF/HSPF2	Verified Heating Cap 47	Verified Heating Cap 17
Heat Pump System 1-hers-htpump	Not Required	0	Required	Required	Yes	Yes	Yes	Yes

01	02	03	04	05	06	07	08	09	10
Name	Certified Low-Static VCHP System	Airflow to Habitable Rooms	Ductless Units in Conditioned Space	Wall Mount Thermostat	Air Filter Sizing & Pressure Drop Rating	Low Leakage Ducts in Conditioned Space	Minimum Airflow per RA3.3 and SC3.3.4.1	Certified non-continuous Fan	Indoor Fan not Running Continuously
Heat Pump System 1	Not required	Required	Required	Required	Not required	Not required	Not required	Not required	Not required

01	02	03	04	05	06	07	08	09
Dwelling Unit	Airflow (CFM)	Fan Efficacy (W/CFM)	IAQ Fan Type	Includes Heat/Energy Recovery?	IAQ Recovery Effectiveness - SRE/ASRE	Includes Fault Indicator Display?	HERS Verification	Status
Sfam IAQVentRpt	36	0.35	Exhaust	No	n/a / n/a	No	Yes	

Registration Number: 425-P010032528A-000-000-0000000-0000  
 Registration Date/Time: 01/31/2025 10:19  
 HERS Provider: CHEERS  
 NOTICE: This document has been generated by California Home Energy Efficiency Rating Services (CHEERS) using information submitted by third parties not affiliated with or related to CHEERS. Therefore, CHEERS is not responsible for, and cannot guarantee, the accuracy or completeness of the information contained in this document.  
 CA Building Energy Efficiency Standards - 2022 Residential Compliance  
 Report Version: 2022.0.000  
 Schema Version: rev 20220901  
 Report Generated: 2025-01-28 22:37:44

**CERTIFICATE OF COMPLIANCE - RESIDENTIAL PERFORMANCE COMPLIANCE METHOD**  
**Project Name:** 705 SQFT ADU  
**Calculation Description:** Title 24 Analysis  
**Calculation Date/Time:** 2025-01-28T22:37:27-08:00  
**Input File Name:** 705 SQFT ADU.rbd22x  
**CF1R-PRF-01-E**  
**(Page 10 of 10)**

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT	
1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name: Maral Rahmani	Documentation Author Signature: 
Company: Title24 Experts	Signature Date: 01/31/2025
Address: 7518 Jumilla Ave.	CEA/ HERS Certification Identification (if applicable): 3105044878
City/State/Zip: Winnetka, CA 91306	Phone: 3105044878
RESPONSIBLE PERSON'S DECLARATION STATEMENT	
I certify the following under penalty of perjury, under the laws of the State of California:	
1. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design identified on this Certificate of Compliance. 2. I certify that the energy features and performance specifications identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. 3. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans, and specifications submitted to the enforcement agency for approval with this building permit application.	
Responsible Designer Name: Maral Rahmani	Responsible Designer Signature: 
Company: Title24 Experts	Date Signed: 01/31/2025
Address: 7518 Jumilla Ave.	License: M-35134
City/State/Zip: Winnetka, CA 91306	Phone: 3105044878

Digitally signed by California Home Energy Efficiency Rating Services (CHEERS). This digital signature is provided in order to secure the content of this registered document, and in no way implies Registration Provider responsibility for the accuracy of the information.  
 Registration Number: 425-P010032528A-000-000-0000000-0000  
 Registration Date/Time: 01/31/2025 10:19  
 HERS Provider: CHEERS  
 NOTICE: This document has been generated by California Home Energy Efficiency Rating Services (CHEERS) using information submitted by third parties not affiliated with or related to CHEERS. Therefore, CHEERS is not responsible for, and cannot guarantee, the accuracy or completeness of the information contained in this document.  
 CA Building Energy Efficiency Standards - 2022 Residential Compliance  
 Report Version: 2022.0.000  
 Schema Version: rev 20220901  
 Report Generated: 2025-01-28 22:37:44



PROJECT  
 PROJECT NAME  
 PROJECT ADDRESS



DISCLAIMER:  
 BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
 1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR; THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
 2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
 3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
 4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
 SCALE  
 PROJECT NO. 230023  
 DATE 08-09-2023

STYLE

DESCRIPTION  
**TITLE 24 ENERGY ANALYSIS**

SHEET  
**T24-2**

BUILDING ENERGY ANALYSIS REPORT	
<b>PROJECT:</b> 705 SQFT ADU CA	<b>RESIDENTIAL MEASURES SUMMARY</b> RMS-1 Project Name: 705 SQFT ADU Building Type: Single Family Date: 1/28/2025
<b>Project Designer:</b> TOM CAMPBELL & ASSOCIATES, INC. 5331 GALLOWAY ST. ALTA LOMA, CA 91301 (951) 741-2107	<b>INSULATION</b> Construction Type: Wood Framed Cavity Area: R-15 808 Special Features: None Status: New
<b>Report Prepared by:</b> Maral Rahmani 7518 JUMILLA AVE. WINNETKA, CA 91306 818-561-9333	<b>FENESTRATION</b> Total Area: 49 Glazing Percentage: 7.0% New/Altered Average U-Factor: 0.30
<b>Job Number:</b> 75-250128-04	<b>HVAC SYSTEMS</b> Qty. Heating: 1 Electric Heat Pump Min. Eff: 8.00 HSPF2 Cooling: Split Heat Pump Min. Eff: 16.0 SEER2 Thermostat: Setback Status: New
<b>Date:</b> 1/28/2025	<b>HVAC DISTRIBUTION</b> Location: New Mini split Heating: Ducted Cooling: Ducted Duct Location: n/a R-Value: n/a Status: New
The EnergyPro computer program has been used to perform the calculations summarized in this compliance report. This program has approval and is authorized by the California Energy Commission for use with both the Residential and Nonresidential 2022 Building Energy Efficiency Standards. This program developed by EnergySoft, LLC - www.energysoft.com.	

2022 Single-Family Residential Mandatory Requirements Summary	
§ 150.0(m)13: Space Conditioning System Airflow Rate and Fan Efficacy. Space conditioning systems that use ducts to supply cooling must have a hole for the placement of a static pressure probe, or a permanently installed static pressure probe in the supply plenum. Airflow must be ≥ 350 CFM per ton of nominal cooling capacity, and an air-handling unit fan efficiency ≤ 0.45 watts per CFM for gas furnace air handlers and ≤ 0.58 watts per CFM for all others. Small duct high velocity systems must provide an airflow ≥ 250 CFM per ton of nominal cooling capacity, and an air-handling unit fan efficiency ≤ 0.62 watts per CFM. Field verification testing is required in accordance with Reference Residential Appendix RA3.3.	§ 150.0(k)1G: Screw based luminaires. Screw based luminaires must contain lamps that comply with Reference Joint Appendix JA8.
§ 150.0(o)1: Requirements for Ventilation and Indoor Air Quality. All dwelling units must meet the requirements of ASHRAE Standard 62.2, and attached dwelling units not sharing ceilings or floors with other dwelling units, occupiable spaces, public garages, or commercial spaces must have mechanical ventilation airflow specified in § 150.0(o)1C.	§ 150.0(k)1H: Light sources in Enclosed or Recessed Luminaires. Lamps and other separate light sources that are not compliant with the JA8 elevated temperature requirements, including marking requirements, must not be installed in enclosed or recessed luminaires.
§ 150.0(o)1B: Central Fan Integrated (CFI) Ventilation Systems. Continuous operation of CFI air handlers is not allowed to provide the whole-dwelling unit ventilation airflow required per § 150.0(o)1C. A motorized damper(s) must be installed on the ventilation duct(s) that prevents air flow through the space conditioning duct system when the damper(s) is closed and controlled per § 150.0(o)1B(4)(i). CFI ventilation systems must have controls that track outdoor air ventilation run time, and either open or close the motorized damper(s) for compliance with § 150.0(o)1C.	§ 150.0(k)1I: Light sources in Drawers, Cabinets, and Linen Closets. Light sources internal to drawers, cabinetry or linen closets are not required to comply with Table 150.0-A or be controlled by vacancy sensors provided that they are rated to consume no more than 5 watts of power, emit no more than 150 lumens, and are equipped with controls that automatically turn the lighting on when the drawer, cabinet or linen closet is closed.
§ 150.0(o)1C: Whole-Dwelling Unit Mechanical Ventilation for Single-Family Detached and townhouses. Single-family detached dwelling units, and attached dwelling units not sharing ceilings or floors with other dwelling units, occupiable spaces, public garages, or commercial spaces must have mechanical ventilation airflow specified in § 150.0(o)1C(4).	§ 150.0(k)2A: Interior Switches and Controls. All forward phase out dimmers used with LED light sources must comply with NEMA SSL 7A.
§ 150.0(o)1G: Local Mechanical Exhaust. Kitchens and bathrooms must have local mechanical exhaust; nonenclosed kitchens must have demand-controlled exhaust system meeting requirements of § 150.0(o)1G(4)(i) enclosed kitchens and bathrooms can use demand-controlled or continuous exhaust meeting § 150.0(o)1G(4)(ii). Airflow must be measured by the installer per § 150.0(o)1G(4)(i), and rated for sound per § 150.0(o)1G(4)(i).	§ 150.0(k)2B: Interior Switches and Controls. Exhaust fans must be controlled separately from lighting systems.
§ 150.0(o)1H: Airflow Measurement and Sound Ratings of Whole-Dwelling Unit Ventilation Systems. The airflow required per § 150.0(o)1C must be measured by using a flow hood, flow grid, or other airflow measuring device at the fan's inlet or outlet terminals per Reference Residential Appendix RA3.7. Whole-dwelling unit ventilation systems must be rated for sound per ASHRAE 62.2 § 7.2 at no less than the minimum airflow rate required by § 150.0(o)1C.	§ 150.0(k)2C: Accessible Controls. Lighting must have readily accessible wall-mounted controls that allow the lighting to be manually turned on and off.
§ 150.0(o)2: Field Verification and Diagnostic Testing. Whole-Dwelling Unit ventilation airflow, vented range hood airflow and sound rating, and HRV and ERV fan efficiency must be verified in accordance with Reference Residential Appendix RA3.7. Vented range hoods must be verified per Reference Residential Appendix RA3.7.4.3 to confirm if it is rated by HVI or AHAM to comply with the airflow rates and sound requirements per § 150.0(o)1G.	§ 150.0(k)2D: Multiple Controls. Controls must not bypass a dimmer, occupant sensor, or vacancy sensor function if the dimmer or sensor is installed to comply with § 150.0(k)2C.
§ 110.4(a): Certification by Manufacturers. Any pool or spa heating system or equipment must be certified to have all of the following: compliance with the Appliance Efficiency Regulations and listing in MAEDS; an on-off switch mounted outside of the heater that allows shutting off the heater without adjusting the thermostat setting; a permanent weatherproof plate or card with operating instructions; and must not use electric resistance heating.	§ 150.0(k)2E: Energy Management Control Systems. An energy management control system (EMCS) may be used to comply with dimming, occupancy, and control requirements if it provides the functionality of the specified control per § 110.9 and the physical controls specified in § 150.0(k)2C.
§ 110.4(b)1: Covers. Outdoor pools or spas that have a heat pump or gas heater must have a cover.	§ 150.0(k)2F: Dimmers. Lighting in habitable spaces (e.g., living rooms, dining rooms, kitchens, and bedrooms) must have readily accessible wall-mounted dimming controls that allow the lighting to be manually adjusted up and down. Forward phase out dimmers controlling LED light sources in these spaces must comply with NEMA SSL 7A.
§ 110.4(b)2: Directional Inlets and Time Switches for Pools. Pools must have directional inlets that adequately mix the pool water, and a time switch that will allow all pumps to be set or programmed to run only during off-peak electric demand periods.	§ 150.0(k)2G: Independent controls. Integrated lighting of exhaust fans shall be controlled independently from the fans. Lighting under cabinets or shelves, lighting in display cabinets, and switched outlets must be controlled separately from ceiling-installed lighting.
§ 110.5: Pilot Light. Natural gas pool and spa heaters must not have a continuously burning pilot light.	§ 150.0(k)2H: Residential Outdoor Lighting. For single-family residential buildings, outdoor lighting permanently mounted to a residential building, or to other buildings on the same lot, must have a manual on/off switch and either a photocell and motion sensor or automatic time switch control) or an astronomical time clock. An energy management control system that provides the specified control functionality and meets all applicable requirements may be used to meet these requirements.
§ 150.0(p): Pool Systems and Equipment Installation. Residential pool systems or equipment must meet the specified requirements for pump sizing, low voltage wiring, or fan speed control.	§ 150.0(k)3A: Internally Illuminated Address Signs. Internally illuminated address signs must either comply with § 140.8 or consume no more than 5 watts of power.
§ 110.9: Lighting Controls and Components. All lighting control devices and systems, ballasts, and luminaires must meet the applicable requirements of § 110.9.	§ 150.0(k)4: Residential Garages for Eight or More Vehicles. Lighting for residential parking garages for eight or more vehicles must comply with the applicable requirements for nonresidential garages in § 110.9, 130.0, 130.1, 130.4, 140.6, and 141.0.
§ 150.0(k)1A: Luminaire Efficacy. All installed luminaires must meet the requirements in Table 150.0-A, except lighting integral to exhaust fans, kitchen range hoods, bath vanity mirrors, and garage door openers; navigation lighting less than 5 watts; and lighting internal to drawers, cabinets, and linen closets with an efficacy of at least 45 lumens per watt.	§ 110.9(a): Solar Readiness: Single-Family Residences. Single-family residences located in subdivisions with 10 or more single-family residences and where the application for a tentative subdivision map for the residences has been deemed complete and approved by the enforcement agency, which do not have a photovoltaic system installed, must comply with the requirements of § 110.10(b)-(e).
§ 150.0(k)1B: Recessed Downlight Luminaires in Ceilings. Luminaires recessed into ceilings must not contain screw based sockets, must be airtight, and must be sealed with a gasket or caulk. California Electrical Code § 410.116 must also be met.	§ 110.10(a)1: Minimum Solar Zone Area. The solar zone must have a minimum total area as described below. The solar zone must comply with access, pathway, smoke ventilation, and spacing requirements as specified in Title 24, Part 9 or other parts of Title 24 or in any requirements adopted by a local jurisdiction. The solar zone total area must be comprised of areas that have no dimension less than 5 feet and are no less than 80 square feet each for buildings with roof areas less than or equal to 10,000 square feet or no less than 160 square feet each for buildings with roof areas greater than 10,000 square feet. For single-family residences, the solar zone must be located on the roof or overhang of the building and have a total area no less than 250 square feet.
§ 150.0(k)1C: Light Sources in Enclosed or Recessed Luminaires. Lamps and other separate light sources that are not compliant with the JA8 elevated temperature requirements, including marking requirements, must not be installed in enclosed or recessed luminaires.	§ 110.10(a)2: Azimuth. All sections of the solar zone located on steep-sloped roofs must have an azimuth between 90-300° of true north.
§ 150.0(k)1D: Blank Electrical Boxes. The number of electrical boxes that are more than five feet above the finished floor and do not contain a luminaire or other device shall be no more than the number of bedrooms. These boxes must be served by a dimmer, vacancy sensor control, low voltage wiring, or fan speed control.	§ 110.10(a)3A: Shading. The solar zone must not contain any obstructions, including but not limited to: vents, chimneys, architectural features, and roof mounted equipment.
§ 150.0(k)1E: Lighting Integral to Exhaust Fans. Lighting integral to exhaust fans (except when installed by the manufacturer in kitchen exhaust hoods) must meet the applicable requirements of § 150.0(k)1E.	§ 110.10(a)3B: Shading. Any obstruction located on the roof or other part of the building that projects above a solar zone must be located at least twice the horizontal distance of the height difference between the highest point of the obstruction and the horizontal projection of the nearest point of the solar zone, measured in the vertical plane.
	§ 110.10(b)4: Structural Design Loads on Construction Documents. For areas of the roof designated as a solar zone, the structural design loads for roof dead load and roof live load must be clearly indicated on the construction documents.
	§ 110.10(c): Interconnection Pathways. The construction documents must indicate a location reserved for inverters and metering equipment and a pathway reserved for routing of conduit from the solar zone to the point of interconnection with the electrical service; and for single-family residences and central water-heating systems, a pathway reserved for routing plumbing from the solar zone to the water-heating system.
	§ 110.10(d): Documentation. A copy of the construction documents or a comparable document indicating the information from § 110.10(b)-(c) must be provided to the occupant.
	§ 110.10(e)1: Main Electrical Service Panel. The main electrical service panel must have a minimum busbar rating of 200 amps.
	§ 110.10(e)2: Main Electrical Service Panel. The main electrical service panel must have a reserved space to allow for the installation of a double pole circuit breaker for a future solar electric installation. The reserved space must be permanently marked as "For Future Solar Electric."

2022 Single-Family Residential Mandatory Requirements Summary	
§ 110.6(a)1: Air Leakage. Manufactured fenestration, exterior doors, and exterior pet doors must limit air leakage to 0.3 CFM per square foot or less when tested per NRC-403, ASTM E283, or AAMA/NWMA CSA 1013.5/21440-2011.	§ 150.0(s): Energy Storage System (ESS) Ready. All single-family residences must meet all of the following: Either ESS-ready interconnection equipment with backed up capacity of 50 amps or more and four or more ESS supplied branch circuits, or a dedicated raceway from the main service to a subpanel that supplies the branch circuits in § 150.0(s); at least four branch circuits must be identified and have their source color-coded at a single panelboard suitable to be supplied by the ESS, with one circuit supplying the refrigerator, one lighting circuit near the primary exit, and one circuit supplying a sleeping room receptacle outlet; main panelboard must have a minimum busbar rating of 225 amps; sufficient space must be reserved to allow future installation of a system isolation equipment/transfer switch within 3' of the main panelboard, with raceways installed between the panelboard and the switch location to allow the connection of backup power source.
§ 110.6(a)5: Labeling. Fenestration products and exterior doors must have a label meeting the requirements of § 10-111(a).	§ 150.0(t): Heat Pump Space Heater Ready. Systems using gas or propane furnaces to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the furnace with circuit conductors rated at least 30 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
§ 110.6(b): Field fabricated exterior doors and fenestration products must use U-Factors and solar heat gain coefficient (SHGC) values from Tables 110.6-A, 110.6-B, or JA4.5 for exterior doors. They must be caulked and/or weather-stripped.	§ 150.0(u): Electric Cooktop Ready. Systems using gas or propane cooktop to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the cooktop with circuit conductors rated at least 50 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
§ 110.7: Air Leakage. All joints, penetrations, and other openings in the building envelope that are weather sources of air leakage must be caulked, gasketed, or weather stripped.	§ 150.0(v): Electric Clothes Dryer Ready. Clothes dryer locations with gas or propane plumbing to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the dryer location with circuit conductors rated at least 30 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
§ 110.8(a): Insulation Certification by Manufacturers. Insulation must be certified by the Department of Consumer Affairs, Bureau of Household Goods and Services (BHGS).	§ 110.9(a): Solar Readiness: Single-Family Residences. Single-family residences located in subdivisions with 10 or more single-family residences and where the application for a tentative subdivision map for the residences has been deemed complete and approved by the enforcement agency, which do not have a photovoltaic system installed, must comply with the requirements of § 110.10(b)-(e).
§ 110.8(b): Insulation Requirements for Heated Slab Floors. Heated slab floors must be insulated per the requirements of § 110.8(b).	§ 110.10(a)1: Minimum Solar Zone Area. The solar zone must have a minimum total area as described below. The solar zone must comply with access, pathway, smoke ventilation, and spacing requirements as specified in Title 24, Part 9 or other parts of Title 24 or in any requirements adopted by a local jurisdiction. The solar zone total area must be comprised of areas that have no dimension less than 5 feet and are no less than 80 square feet each for buildings with roof areas less than or equal to 10,000 square feet or no less than 160 square feet each for buildings with roof areas greater than 10,000 square feet. For single-family residences, the solar zone must be located on the roof or overhang of the building and have a total area no less than 250 square feet.
§ 110.8(c): Roofing Products Solar Reflectance and Thermal Emittance. The thermal emittance and aged solar reflectance values of the roofing material must meet the requirements of § 110.8(c) and be labeled per § 10-113 when the installation of a cool roof is specified on the CFIR.	§ 110.10(a)2: Azimuth. All sections of the solar zone located on steep-sloped roofs must have an azimuth between 90-300° of true north.
§ 110.8(d): Radiant Barrier. When required, radiant barriers must have an emittance of 0.05 or less and be certified to the Department of Consumer Affairs.	§ 110.10(a)3A: Shading. The solar zone must not contain any obstructions, including but not limited to: vents, chimneys, architectural features, and roof mounted equipment.
§ 150.0(a): Roof Deck, Ceiling and Rafter Roof Insulation. Roof decks in newly constructed attics in climate zones 4 and 8-16 area-weighted average U-factor not exceeding U-0.184. Ceiling and rafter roofs minimum R-22 insulation in wood-frame ceiling, or area-weighted average U-factor not exceed 0.043. Rafter roof alterations minimum R-19 or area-weighted average U-factor of 0.054 or less. Attic access doors must have permanently attached insulation using adhesive or mechanical fasteners. The attic access must be gasketed to prevent air leakage. Insulation must be installed in direct contact with a roof or ceiling which is sealed to limit infiltration and exfiltration, as specified in § 110.7, including but not limited to placing insulation either above or below the roof deck or on top of a drywall ceiling.	§ 110.10(a)3B: Shading. Any obstruction located on the roof or other part of the building that projects above a solar zone must be located at least twice the horizontal distance of the height difference between the highest point of the obstruction and the horizontal projection of the nearest point of the solar zone, measured in the vertical plane.
§ 150.0(b): Loose-fill Insulation. Loose fill insulation must meet the manufacturer's required density for the labeled R-value.	§ 110.10(b)4: Structural Design Loads on Construction Documents. For areas of the roof designated as a solar zone, the structural design loads for roof dead load and roof live load must be clearly indicated on the construction documents.
§ 150.0(c): Wall Insulation. Minimum R-13 insulation in 2x4 inch wood framing wall or have a U-factor of 0.102 or less, or R-20 in 2x6 inch wood framing or have a U-factor of 0.071 or less. Opaque non-framed assemblies must have an overall assembly U-factor not exceeding 0.102. Masonry walls must meet Tables 150.1-A or B.	§ 110.10(c): Interconnection Pathways. The construction documents must indicate a location reserved for inverters and metering equipment and a pathway reserved for routing of conduit from the solar zone to the point of interconnection with the electrical service; and for single-family residences and central water-heating systems, a pathway reserved for routing plumbing from the solar zone to the water-heating system.
§ 150.0(d): Raised-floor Insulation. Minimum R-19 insulation in raised wood framed floor or 0.037 maximum U-factor.	§ 110.10(d): Documentation. A copy of the construction documents or a comparable document indicating the information from § 110.10(b)-(c) must be provided to the occupant.
§ 150.0(f): Slab Edge Insulation. Slab edge insulation must meet all of the following: have a water absorption rate, for the insulation material alone without facings, no greater than 0.3 percent; have a water vapor permeance no greater than 2.0 perm per inch; be protected from physical damage and UV light deterioration; and, when installed as part of a heated slab floor, meet the requirements of § 110.8(g).	§ 110.10(e)1: Main Electrical Service Panel. The main electrical service panel must have a minimum busbar rating of 200 amps.
§ 150.0(g)1: Vapor Retarder. In climate zones 1 through 16, the earth floor of unvented crawl space must be covered with a Class I or Class II vapor retarder. This requirement also applies to controlled ventilation crawl space for buildings complying with the exception to § 150.0(g).	§ 110.10(e)2: Main Electrical Service Panel. The main electrical service panel must have a reserved space to allow for the installation of a double pole circuit breaker for a future solar electric installation. The reserved space must be permanently marked as "For Future Solar Electric."
§ 150.0(g)2: Vapor Retarder. In climate zones 14 and 16, a Class I or Class II vapor retarder must be installed on the conditioned space side of all insulation in all exterior walls, vented attics, and unvented attics with air-permeable insulation.	
§ 150.0(g): Fenestration Products. Fenestration, including skylights, separating conditioned space from unconditioned space or outdoors must have a maximum U-factor of 0.45, or area-weighted average U-factor of all fenestration must not exceed 0.45.	
§ 150.0(h): Fireplaces, Decorative Gas Appliances, and Gas Log: § 110.5(a): Pilot Light. Continuously burning pilot lights are not allowed for indoor and outdoor fireplaces.	
§ 150.0(i)1: Cleasable Doors. Masonry or factory-built fireplaces must have a cleasable metal or glass door covering the entire opening of the firebox.	
§ 150.0(i)2: Combustion Intake. Masonry or factory-built fireplaces must have a combustion outside air intake, which is at least six square inches in area and is equipped with a readily accessible, operable, and light-fitting damper or combustion-air control device.	
§ 150.0(i)3: Flue Damper. Masonry or factory-built fireplaces must have a flue damper with a readily accessible control.	
§ 110.2(c): Insulation. Unfired service water storage tanks and solar water-heating backup tanks must have adequate insulation, or tank surface heat loss rating.	
§ 110.3(c)3: Isolation Valves. Instantaneous water heaters with an input rating greater than 6.8 kBtu per hour (2 kW) must have isolation valves with hose bibbs or other fittings on both cold and hot water lines to allow for flushing the water heater when the valves are closed.	

2022 Single-Family Residential Mandatory Requirements Summary	
§ 110.6(a)1: Air Leakage. Manufactured fenestration, exterior doors, and exterior pet doors must limit air leakage to 0.3 CFM per square foot or less when tested per NRC-403, ASTM E283, or AAMA/NWMA CSA 1013.5/21440-2011.	§ 150.0(s): Energy Storage System (ESS) Ready. All single-family residences must meet all of the following: Either ESS-ready interconnection equipment with backed up capacity of 50 amps or more and four or more ESS supplied branch circuits, or a dedicated raceway from the main service to a subpanel that supplies the branch circuits in § 150.0(s); at least four branch circuits must be identified and have their source color-coded at a single panelboard suitable to be supplied by the ESS, with one circuit supplying the refrigerator, one lighting circuit near the primary exit, and one circuit supplying a sleeping room receptacle outlet; main panelboard must have a minimum busbar rating of 225 amps; sufficient space must be reserved to allow future installation of a system isolation equipment/transfer switch within 3' of the main panelboard, with raceways installed between the panelboard and the switch location to allow the connection of backup power source.
§ 110.6(a)5: Labeling. Fenestration products and exterior doors must have a label meeting the requirements of § 10-111(a).	§ 150.0(t): Heat Pump Space Heater Ready. Systems using gas or propane furnaces to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the furnace with circuit conductors rated at least 30 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
§ 110.7: Air Leakage. All joints, penetrations, and other openings in the building envelope that are weather sources of air leakage must be caulked, gasketed, or weather stripped.	§ 150.0(u): Electric Cooktop Ready. Systems using gas or propane cooktop to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the cooktop with circuit conductors rated at least 50 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
§ 110.8(a): Insulation Certification by Manufacturers. Insulation must be certified by the Department of Consumer Affairs, Bureau of Household Goods and Services (BHGS).	§ 150.0(v): Electric Clothes Dryer Ready. Clothes dryer locations with gas or propane plumbing to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the dryer location with circuit conductors rated at least 30 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
§ 110.8(b): Insulation Requirements for Heated Slab Floors. Heated slab floors must be insulated per the requirements of § 110.8(b).	§ 110.9(a): Solar Readiness: Single-Family Residences. Single-family residences located in subdivisions with 10 or more single-family residences and where the application for a tentative subdivision map for the residences has been deemed complete and approved by the enforcement agency, which do not have a photovoltaic system installed, must comply with the requirements of § 110.10(b)-(e).
§ 110.8(c): Roofing Products Solar Reflectance and Thermal Emittance. The thermal emittance and aged solar reflectance values of the roofing material must meet the requirements of § 110.8(c) and be labeled per § 10-113 when the installation of a cool roof is specified on the CFIR.	§ 110.10(a)1: Minimum Solar Zone Area. The solar zone must have a minimum total area as described below. The solar zone must comply with access, pathway, smoke ventilation, and spacing requirements as specified in Title 24, Part 9 or other parts of Title 24 or in any requirements adopted by a local jurisdiction. The solar zone total area must be comprised of areas that have no dimension less than 5 feet and are no less than 80 square feet each for buildings with roof areas less than or equal to 10,000 square feet or no less than 160 square feet each for buildings with roof areas greater than 10,000 square feet. For single-family residences, the solar zone must be located on the roof or overhang of the building and have a total area no less than 250 square feet.
§ 110.8(d): Radiant Barrier. When required, radiant barriers must have an emittance of 0.05 or less and be certified to the Department of Consumer Affairs.	§ 110.10(a)2: Azimuth. All sections of the solar zone located on steep-sloped roofs must have an azimuth between 90-300° of true north.
§ 150.0(a): Roof Deck, Ceiling and Rafter Roof Insulation. Roof decks in newly constructed attics in climate zones 4 and 8-16 area-weighted average U-factor not exceeding U-0.184. Ceiling and rafter roofs minimum R-22 insulation in wood-frame ceiling, or area-weighted average U-factor not exceed 0.043. Rafter roof alterations minimum R-19 or area-weighted average U-factor of 0.054 or less. Attic access doors must have permanently attached insulation using adhesive or mechanical fasteners. The attic access must be gasketed to prevent air leakage. Insulation must be installed in direct contact with a roof or ceiling which is sealed to limit infiltration and exfiltration, as specified in § 110.7, including but not limited to placing insulation either above or below the roof deck or on top of a drywall ceiling.	§ 110.10(a)3A: Shading. The solar zone must not contain any obstructions, including but not limited to: vents, chimneys, architectural features, and roof mounted equipment.
§ 150.0(b): Loose-fill Insulation. Loose fill insulation must meet the manufacturer's required density for the labeled R-value.	§ 110.10(a)3B: Shading. Any obstruction located on the roof or other part of the building that projects above a solar zone must be located at least twice the horizontal distance of the height difference between the highest point of the obstruction and the horizontal projection of the nearest point of the solar zone, measured in the vertical plane.
§ 150.0(c): Wall Insulation. Minimum R-13 insulation in 2x4 inch wood framing wall or have a U-factor of 0.102 or less, or R-20 in 2x6 inch wood framing or have a U-factor of 0.071 or less. Opaque non-framed assemblies must have an overall assembly U-factor not exceeding 0.102. Masonry walls must meet Tables 150.1-A or B.	§ 110.10(b)4: Structural Design Loads on Construction Documents. For areas of the roof designated as a solar zone, the structural design loads for roof dead load and roof live load must be clearly indicated on the construction documents.
§ 150.0(d): Raised-floor Insulation. Minimum R-19 insulation in raised wood framed floor or 0.037 maximum U-factor.	§ 110.10(c): Interconnection Pathways. The construction documents must indicate a location reserved for inverters and metering equipment and a pathway reserved for routing of conduit from the solar zone to the point of interconnection with the electrical service; and for single-family residences and central water-heating systems, a pathway reserved for routing plumbing from the solar zone to the water-heating system.
§ 150.0(f): Slab Edge Insulation. Slab edge insulation must meet all of the following: have a water absorption rate, for the insulation material alone without facings, no greater than 0.3 percent; have a water vapor permeance no greater than 2.0 perm per inch; be protected from physical damage and UV light deterioration; and, when installed as part of a heated slab floor, meet the requirements of § 110.8(g).	§ 110.10(d): Documentation. A copy of the construction documents or a comparable document indicating the information from § 110.10(b)-(c) must be provided to the occupant.
§ 150.0(g)1: Vapor Retarder. In climate zones 1 through 16, the earth floor of unvented crawl space must be covered with a Class I or Class II vapor retarder. This requirement also applies to controlled ventilation crawl space for buildings complying with the exception to § 150.0(g).	§ 110.10(e)1: Main Electrical Service Panel. The main electrical service panel must have a minimum busbar rating of 200 amps.
§ 150.0(g)2: Vapor Retarder. In climate zones 14 and 16, a Class I or Class II vapor retarder must be installed on the conditioned space side of all insulation in all exterior walls, vented attics, and unvented attics with air-permeable insulation.	§ 110.10(e)2: Main Electrical Service Panel. The main electrical service panel must have a reserved space to allow for the installation of a double pole circuit breaker for a future solar electric installation. The reserved space must be permanently marked as "For Future Solar Electric."
§ 150.0(g): Fenestration Products. Fenestration, including skylights, separating conditioned space from unconditioned space or outdoors must have a maximum U-factor of 0.45, or area-weighted average U-factor of all fenestration must not exceed 0.45.	
§ 150.0(h): Fireplaces, Decorative Gas Appliances, and Gas Log: § 110.5(a): Pilot Light. Continuously burning pilot lights are not allowed for indoor and outdoor fireplaces.	
§ 150.0(i)1: Cleasable Doors. Masonry or factory-built fireplaces must have a cleasable metal or glass door covering the entire opening of the firebox.	
§ 150.0(i)2: Combustion Intake. Masonry or factory-built fireplaces must have a combustion outside air intake, which is at least six square inches in area and is equipped with a readily accessible, operable, and light-fitting damper or combustion-air control device.	
§ 150.0(i)3: Flue Damper. Masonry or factory-built fireplaces must have a flue damper with a readily accessible control.	
§ 110.2(c): Insulation. Unfired service water storage tanks and solar water-heating backup tanks must have adequate insulation, or tank surface heat loss rating.	
§ 110.3(c)3: Isolation Valves. Instantaneous water heaters with an input rating greater than 6.8 kBtu per hour (2 kW) must have isolation valves with hose bibbs or other fittings on both cold and hot water lines to allow for flushing the water heater when the valves are closed.	

2022 Single-Family Residential Mandatory Requirements Summary	
§ 110.5: Pilot Lights. Continuously burning pilot lights are prohibited for natural gas; fan-type central furnaces; household cooking appliances (except appliances without an electrical supply voltage connection with pilot gas that consume less than 150 Btu per hour); and pool and spa heaters.	§ 150.0(m)1: Porous Inner Core Flex Duct. Porous inner cores of flex ducts must have a non-porous layer or air barrier between the inner core and outer vapor barrier.
§ 150.0(h)1: Building Cooling and Heating Loads. Heating and/or cooling loads are calculated in accordance with the ASHRAE Handbook, Equipment Volume, Applications Volume, and Fundamentals Volume; the SMACNA Residential Comfort System Installation Standards Manual; or the ACCA Manual L/air design conditions specified in § 150.0(h)2.	§ 150.0(m)2: Factory-Fabricated Duct Systems. Factory-fabricated duct systems must comply with applicable requirements for duct construction, connections, and closures; joints and seams of duct systems and their components must not be sealed with cloth back rubber adhesive duct tapes unless such tape is used in combination with mastic and drain bands.
§ 150.0(h)3A: Clearances. Air conditioner and heat pump outdoor condensing units must have a clearance of at least five feet from the outlet of any dryer.	§ 150.0(m)3: Field-Fabricated Duct Systems. Field-fabricated duct systems must comply with applicable requirements for pressure-sensitive tapes, mastics, sealants, and other requirements specified for duct construction.
§ 150.0(h)3B: Liquid Line Drier. Air conditioners and heat pump systems must be equipped with liquid line filter driers if required, as specified by the manufacturer's instructions.	§ 150.0(m)7: Backdraft Damper. Fan systems that exchange air between the conditioned space and outdoors must have backdraft or automatic dampers.
§ 150.0(j): Water Piping, Solar Water-heating System Piping, and Space Conditioning System Line Insulation. All domestic hot water piping must be insulated as specified in § 609.11 of the California Plumbing Code.	§ 150.0(m)8: Gravity Ventilation Dampers. Gravity ventilating systems serving conditioned space must have either automatic or readily accessible, manually operated dampers in all openings to the outside, except combustion inlet and outlet air openings and elevator shaft vents.
§ 150.0(j)2: Insulation Protection. Piping insulation must be protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind as required by § 120.3(b). Insulation exposed to weather must be water retardant and protected from UV light (no adhesive tapes). Insulation covering chilled water piping and refrigerant suction piping located outside the conditioned space must include, or be protected by, a Class I or Class II vapor retarder. Pipe insulation buried below grade must be installed in a waterproof and non-crushable casing or sleeve.	§ 150.0(m)9: Protection of Insulation. Insulation must be protected from damage due to sunlight, moisture, equipment maintenance, and wind. Insulation exposed to weather must be suitable for outdoor service (e.g., protected by aluminum, sheet metal, painted canvas, or plastic cover). Cellular foam insulation must be protected as above or painted with a water retardant and solar radiation-resistant coating.
§ 150.0(j)1: Gas or Propane Water Heating Systems. Systems using gas or propane water heaters to serve individual dwelling units must designate a space at least 2.5' x 2.5' x 7' suitable for the future installation of a heat pump water heater, and meet electrical and plumbing requirements, based on the distance between this designated space and the water heater location; and a condensate drain no more than 2' higher than the base of the water heater.	§ 150.0(m)10: Duct System Sealing and Leakage Test. When space conditioning systems use forced air duct systems to supply conditioned air to an occupiable space, the ducts must be sealed and duct leakage tested, as confirmed through field verification and diagnostic testing, in accordance with Reference Residential Appendix RA3.1.
§ 150.0(j)3: Solar Water-heating Systems. Solar water-heating systems and collectors must be certified and rated by the Solar Rating and Certification Corporation (SRCC), the International Association of Plumbing and Mechanical Officials, Research and Testing (IAPMO RPT), or by a listing agency that is approved by the executive director.	§ 150.0(m)12: Air Filtration. Space conditioning systems with ducts exceeding 10 feet and the supply side of ventilation systems must have MERV 13 or equivalent filters. Filters for space conditioning systems must have a two inch depth or can be one inch if sized per Equation 150.0-A. Clear-filer pressure drop and labeling must meet the requirements in § 150.0(m)12. Filters must be accessible for regular service. Filter racks or grilles must use gaskets, sealing, or other means to close gaps around the inserted filters to and prevents air from bypassing the filter.
§ 110.6(a)1: Air Leakage. Manufactured fenestration, exterior doors, and exterior pet doors must limit air leakage to 0.3 CFM per square foot or less when tested per NRC-403, ASTM E283, or AAMA/NWMA CSA 1013.5/21440-2011.	
§ 110.6(a)5: Labeling. Fenestration products and exterior doors must have a label meeting the requirements of § 10-111(a).	
§ 110.7: Air Leakage. All joints, penetrations, and other openings in the building envelope that are weather sources of air leakage must be caulked, gasketed, or weather stripped.	
§ 110.8(a): Insulation Certification by Manufacturers. Insulation must be certified by the Department of Consumer Affairs, Bureau of Household Goods and Services (BHGS).	
§ 110.8(b): Insulation Requirements for Heated Slab Floors. Heated slab floors must be insulated per the requirements of § 110.8(b).	
§ 110.8(c): Roofing Products Solar Reflectance and Thermal Emittance. The thermal emittance and aged solar reflectance values of the roofing material must meet the requirements of § 110.8(c) and be labeled per § 10-113 when the installation of a cool roof is specified on the CFIR.	
§ 110.8(d): Radiant Barrier. When required, radiant barriers must have an emittance of 0.05 or less and be certified to the Department of Consumer Affairs.	
§ 150.0(a): Roof Deck, Ceiling and Rafter Roof Insulation. Roof decks in newly constructed attics in climate zones 4 and 8-16 area-weighted average U-factor not exceeding U-0.184. Ceiling and rafter roofs minimum R-22 insulation in wood-frame ceiling, or area-weighted average U-factor not exceed 0.043. Rafter roof alterations minimum R-19 or area-weighted average U-factor of 0.054 or less. Attic access doors must have permanently attached insulation using adhesive or mechanical fasteners. The attic access must be gasketed to prevent air leakage. Insulation must be installed in direct contact with a roof or ceiling which is sealed to limit infiltration and exfiltration, as specified in § 110.7, including but not limited to placing insulation either above or below the roof deck or on top of a drywall ceiling.	
§ 150.0(b): Loose-fill Insulation. Loose fill insulation must meet the manufacturer's required density for the labeled R-value.	
§ 150.0(c): Wall Insulation. Minimum R-13 insulation in 2x4 inch wood framing wall or have a U-factor of 0.1	





TABLE R702.3.5 MINIMUM THICKNESS AND APPLICATION OF GYPSUM BOARD AND GYPSUM PANEL PRODUCTS

THICKNESS OF GYPSUM BOARD OR GYPSUM PANEL PRODUCTS (inches)	APPLICATION	ORIENTATION OF GYPSUM BOARD OR GYPSUM PANEL PRODUCTS TO FRAMING	MAXIMUM SPACING OF FRAMING MEMBERS (inches o.c.)	MAXIMUM SPACING OF FASTENERS (inches)		SIZE OF NAILS FOR APPLICATION TO WOOD FRAMING <sup>a</sup>
				Nails <sup>a</sup>	Screws <sup>b</sup>	
<b>Application without adhesive</b>						
3/8	Ceiling <sup>d</sup>	Perpendicular	16	7	12	13 gage, 1 1/4" long, 19/64" head; 0.098" diameter, 1 1/4" long, ring shank; or 4d cooler nail, 0.080" diameter, 1 3/8" long, 7/32" head.
	Wall	Either direction	16	8	16	
1/2	Ceiling	Either direction	16	7	12	13 gage, 1 3/8" long, 19/64" head; 0.098" diameter, 1 1/4" long, ring shank; 5d cooler nail, 0.086" diameter, 1 5/8" long, 15/64" head; or gypsum board nail, 0.086" diameter, 1 5/8" long, 9/32" head.
	Ceiling <sup>d</sup>	Perpendicular	24	7	12	
	Wall	Either direction	24	8	12	
5/8	Wall	Either direction	16	8	16	
	Ceiling	Either direction	16	7	12	13 gage, 1 3/8" long, 19/64" head; 0.098" diameter, 1 3/8" long, ring shank; 6d cooler nail, 0.092" diameter, 1 7/8" long, 1/4" head; or gypsum board nail, 0.0915" diameter, 1 7/8" long, 19/64" head.
	Ceiling	Perpendicular	24	7	12	
	Type X at garage ceiling beneath habitable rooms	Perpendicular	24	6	6	1 7/8" long 0.099" diameter galvanized nails or equivalent drywall screws. Screws shall comply with Section R702.3.5.1.
5/8	Wall	Either direction	24	8	12	13 gage, 1 3/8" long, 19/64" head; 0.098" diameter, 1 3/8" long, ring shank; 6d cooler nail, 0.092" diameter, 1 7/8" long, 1/4" head; or gypsum board nail, 0.0915" diameter, 1 7/8" long, 19/64" head.
	Wall	Either direction	16	8	16	
<b>Application with adhesive</b>						
3/8	Ceiling <sup>d</sup>	Perpendicular	16	16	16	Same as above for 3/8" gypsum board and gypsum panel products.
	Wall	Either direction	16	16	24	
1/2 or 5/8	Ceiling	Either direction	16	16	16	Same as above for 1/2" and 5/8" gypsum board and gypsum panel products, respectively.
	Ceiling <sup>d</sup>	Perpendicular	24	12	16	
Two 3/8 layers	Wall	Either direction	24	16	24	
	Ceiling	Perpendicular	16	16	16	Base ply nailed as above for 1/2" gypsum board and gypsum panel products; face ply installed with an adhesive.

For SI: 1 inch = 25.4 mm.

- For application without adhesive, a pair of nails spaced not less than 2 inches apart or more than 2 1/2 inches apart shall be permitted to be used with the pair of nails spaced 12 inches on center.
- Screws shall be in accordance with Section R702.3.5.1. Screws for attaching gypsum board or gypsum panel products to structural insulated panels shall penetrate the wood structural panel facing not less than 7/16 inch.
- Where cold-formed steel framing is used with a clinching design to receive nails by two edges of metal, the nails shall be not less than 1/16 inch longer than the gypsum board or gypsum panel product thickness and shall have ringed shanks. Where the cold-formed steel framing has a nailing groove formed to receive the nails, the nails shall have barbed shanks or be 0.088-inch diameter, 1 3/8 inches long, 19/64-inch head for 1/2-inch gypsum board or gypsum panel product, and 0.090-inch diameter, 1 7/8 inches long, 19/64-inch head for 5/8-inch gypsum board or gypsum panel product.
- Three-eighths-inch-thick single-ply gypsum board or gypsum panel product shall not be used on a ceiling where a water-based textured finish is to be applied, or where it will be required to support insulation above a ceiling. On ceiling applications to receive a water-based texture material, either hand or spray applied, the gypsum board or gypsum panel product shall be applied perpendicular to framing. Where applying a water-based texture material, the minimum gypsum board thickness shall be increased from 3/8 inch to 1/2 inch for 16-inch on center framing, and from 1/2 inch to 5/8 inch for 24-inch on center framing or 1/2-inch sag-resistant gypsum ceiling board shall be used.

**FIRE BLOCKING MUST BE PROVIDED IN ACCORDANCE WITH CRC SECTION R302.11 AT THE FOLLOWING LOCATIONS:**

- IN CONCEALED SPACES OF STUD WALLS AND PARTITIONS, INCLUDING FURRED SPACES, AT THE CEILING LEVEL.
- IN CONCEALED SPACES OF STUD WALLS AND PARTITIONS, INCLUDING FURRED SPACES, AT 10-FOOT INTERVALS ALONG THE LENGTH OF THE WALL.
- AT ALL INTERCONNECTIONS BETWEEN CONCEALED VERTICAL AND HORIZONTAL SPACES SUCH AS OCCUR AT SOFFITS, DROP CEILINGS AND COVE CEILINGS.
- AT ANNULAR OPENINGS AROUND VENTS, PIPES, DUCTS, CABLES AND WIRES AT CEILING LEVEL, WITH AN APPROVED MATERIAL TO RESIST THE FREE PASSAGE OF FLAME AND PRODUCTS OF COMBUSTION.

**BEST MANAGEMENT PRACTICE AND CONSTRUCTION ACTIVITIES**

JOB ADDRESS \_\_\_\_\_ PERMIT# \_\_\_\_\_  
 DEPARTMENT OF BUILDING AND SAFETY  
 STORM WATER POLLUTION CONTROL REQUIREMENTS FOR ALL DEVELOPMENT CONSTRUCTION PROJECTS / CERTIFICATION STATEMENTS

THE FOLLOWING IS INTENDED AS AN ATTACHMENT FOR CONSTRUCTION AND GRADING PLANS AND REPRESENT THE MINIMUM STANDARDS FOR GOOD HOUSEKEEPING WHICH MUST BE IMPLEMENTED ON ALL CONSTRUCTION SITES REGARDLESS OF SIZE.

DEVELOPMENT CONSTRUCTION PROJECT ARE DEFINED AS PROJECT WHERE THERE IS LESS THAN TWO ACRES OF DISTURBED SOIL, NOT LOCATED IN DESIGNATED HILLSIDE AREAS, AND NOT IN OR ADJACENT TO ENVIRONMENTAL SENSITIVE AREAS. NOTE: A PROJECT IN A DESIGNATED HILLSIDE AREA WITH LESS THAN TWO ACRES OF DISTURBED SOIL AND NOT IN OR ADJACENT TO AN ENVIRONMENTAL SENSITIVE AREA MAY BE CLASSIFIED AS A DEVELOPMENT CONSTRUCTION PROJECT IF THE GRADING PRE-INSPECTION (GPI) IS NOT REQUIRED OR THE ENTIRE LOT HAS A SLOPE OF TEN PERCENT OR LESS.

- ERODED SEDIMENT AND OTHER POLLUTANTS MUST BE RETAINED ON SITE AND MAY NOT BE TRANSPORTED FROM THE SITE VIA SHEET FLOW, SWELLS, AREA DRAINS, NATURAL DRAINAGE.
- STOCKPILES OF EARTH AND OTHER CONSTRUCTION RELATED MATERIALS MUST BE PROTECTED FROM BEING TRANSPORTED FROM THE SITE BY THE FORCE OF WIND OR WATER.
- FUELS, OILS, SOLVENTS AND OTHER TOXIC MATERIALS MUST BE STORED IN ACCORDANCE WITH THEIR LISTING AND ARE NOT TO CONTAMINATE THE SOIL AND SURFACE WATERS. ALL APPROVED STOCK PILES OF EARTH AND OTHER CONSTRUCTION RELATED MATERIALS MUST BE PROTECTED FROM BEING TRANSPORTED FROM THE SITE BY THE FORCES OF WIND OR WATER.
- STORAGE CONTAINERS ARE TO BE PROTECTED FROM THE WEATHER. SPILLS MUST BE CLEANED UP IMMEDIATELY AND DISPOSED OF IN A PROPER MANNER. SPILLS MAY NOT BE WASHED INTO THE DRAINAGE SYSTEM. EXCESS OR WASTE CONCRETE MAY NOT BE WASHED INTO THE PUBLIC WAY OR ANY OTHER DRAINAGE SYSTEM. PROVISIONS SHALL BE MADE TO RETAIN CONCRETE WASTES ON SITE UNTIL THEY CAN BE DISPOSED OF AS SOLID WASTE.
- TRASH AND CONSTRUCTIONS RELATED SOLID WASTES MUST BE DEPOSITED INTO A COVERED RECEPTACLE TO PREVENT CONTAMINATION OF RAIN WATER AND DISPERSAL BY WIND.
- SEDIMENTS AND OTHER MATERIALS MAY NOT BE TRACKED FROM THE SITE BY VEHICLE TRAFFIC. THE CONSTRUCTION ENTRANCE ROAD WAYS MUST BE STABILIZED SO AS TO INHIBIT SEDIMENTS FROM BEING DEPOSITED INTO THE PUBLIC WAY. ACCIDENTAL DEPOSITIONS MUST BE SWEEPED UP IMMEDIATELY AND MAY NOT BE WASHED DOWN BY RAIN OR OTHER MEANS.
- ANY SLOPES WITH DISTURBED SOILS OR DENUDED OF VEGETATION MUST BE STABILIZED SO AS TO INHIBIT EROSION BY WIND AND WATER.

OTHER:

AS THE PROJECT OWNER OR AUTHORIZED AGENT OF OWNER, I HAVE READ AND UNDERSTAND THE REQUIREMENTS, LISTED ABOVE, NECESSARY TO CONTROL STORM WATER POLLUTION FROM SEDIMENTS, EROSION, CONSTRUCTION MATERIALS, I CERTIFY THAT I WILL COMPLY WITH THESE REQUIREMENTS.

PRINT NAME: \_\_\_\_\_ DATE: \_\_\_\_\_  
 (OWNER OR AUTHORIZED AGENT OF OWNER)

SIGNATURE: \_\_\_\_\_  
 (OWNER OR AUTHORIZED AGENT OF OWNER)

**ADDT'L NOTES:**

PROVISIONS SHALL BE MADE FOR CONTRIBUTORY DRAINAGE AT ALL TIMES. OWNER WILL MAINTAIN DRAINAGE DEVICES AND KEEP FREE OF DEBRIS. AN EXCAVATION / ENCROACHMENT PERMIT IS REQUIRED FOR CONSTRUCTION AND / OR DISCHARGE OF DRAINAGE WITHIN PUBLIC ROAD RIGHT-OF-WAY. (COUNTY OF LOS ANGELES) NO WORK IS ALLOWED WITHIN THE PROTECTED ZONE OF OAK TREE WITHOUT REPORT AND PERMIT. ELEVATE THE FINISH FLOOR 6 INCHES MINIMUM ABOVE NATURAL OR FINISHED GRADE.

AS THE DESIGNEE OF RECORD, I HAVE SELECTED APPROPRIATE BMP'S TO EFFECTIVELY MINIMIZE THE NEGATIVE IMPACTS OF THIS PROJECT'S CONSTRUCTION ACTIVITIES ON STORM WATER QUALITY. THE PROJECT OWNER AND CONTRACTOR ARE AWARE THAT THE SELECTED BMP'S MUST BE INSTALLED, MONITORED, AND MAINTAINED TO ENSURE THEIR EFFECTIVENESS. THE BMP'S NOT SELECTED FOR IMPLEMENTATION ARE REDUNDANT OR DEEMED NOT APPLICABLE TO THE PROPOSED CONSTRUCTION ACTIVITIES.

NAME: ERIC NEGRETE, GRIT DESIGN GROUP, INC.  
 POSITION: DESIGNER  
 DATE:

"I CERTIFY THAT THE PROPOSED WORK WILL NOT DESTROY OR UNREASONABLY INTERFERE WITH ANY ACCESS OR UTILITY EASEMENT BELONGING TO OTHERS AND LOCATED ON MY PROPERTY, BUT IN THE EVENT SUCH WORK DOES DESTROY OR UNREASONABLY INTERFERE WITH SUCH EASEMENT, A SUBSTITUTE EASEMENT(S) SATISFACTORY TO THE HOLDER(S) OF THE EASEMENT WILL BE PROVIDED"

\_\_\_\_\_  
 SIGNATURE TITLE  
 \_\_\_\_\_  
 PRINT NAME DATE



970-546-2387  
 llbuilders.com

PROJECT  
 PROJECT NAME  
 PROJECT ADDRESS



DISCLAIMER:  
 BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

- THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
- THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
- THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
- IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
 SCALE  
 PROJECT NO. 230023  
 DATE 08-09-2023



STYLE

DESCRIPTION  
**BEST MANAGEMENT PRACTICES | APPLICATION OF GYPSUM BOARD | FIRE BLOCKING NOTES**

SHEET  
**A0.0**

# FLOOR PLAN

1/4" = 1'-0"




- MINIMUM ROOM DIMENSIONS (R304 & R305)**
- HABITABLE ROOMS SHALL HAVE A FLOOR AREA OF NOT LESS THAN 70 SF.
  - HABITABLE ROOMS SHALL NOT BE LESS THAN 7 FT. IN ANY HORIZONTAL DIMENSION.
  - HABITABLE SPACE AND HALLWAYS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 7 FT. BATHROOMS, TOILET ROOMS, AND LAUNDRY ROOMS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 6'-8".


### MINIMUM BATHROOM REQ.

NOTE:  
ULTRA LOW FLUSH (1.6 GALLONS MAX)  
TOILET REQ.  
(2016 CPC 402.2)

NOTE:  
SHOWER STALL TO BE  
1024 SQ.IN. MIN. INT.  
(2016 CPC 411.7)



### WINDOW EGRESS DETAIL



### ADU LIGHT & VENTILATION REQUIREMENTS

(N) ENTRY / LIVING ROOM / KITCHEN / DINING		LIGHT REQ.	
<b>VENTILATION REQ.</b>		<b>WINDOWS</b>	
1-4040.....	8.00 SQ.FT.	1-4040.....	16.00 SQ.FT.
2-3040.....	12.00 SQ.FT.	2-3040.....	24.00 SQ.FT.
1-3040.....	6.00 SQ.FT.	1-3040.....	12.00 SQ.FT.
<b>DOORS</b>		<b>DOORS (GLASS)</b>	
1-3068.....	20.00 SQ.FT.	1-2058.....	11.50 SQ.FT.
1-6068.....	40.00 SQ.FT.	1-4058.....	23.00 SQ.FT.
<b>TOTAL OPENABLE AREA.....</b>		<b>TOTAL GLASS AREA.....</b>	
86.00 SQ.FT.		86.50 SQ.FT.	
<b>TOTAL FLOOR AREA.....</b>		<b>TOTAL FLOOR AREA.....</b>	
343 SQ.FT.		343 SQ.FT.	
25.0% OPENABLE FOR REQ. VENT. - OK!		25.2% FOR REQ. LIGHT - OK!	

(N) BEDROOM 1		LIGHT REQ.	
<b>VENTILATION REQ.</b>		<b>WINDOW</b>	
1-4040.....	8.00 SQ.FT.	1-4040.....	16.00 SQ.FT.
<b>TOTAL OPENABLE AREA.....</b>		<b>TOTAL OPENABLE AREA.....</b>	
8.00 SQ.FT.		16.00 SQ.FT.	
<b>TOTAL FLOOR AREA.....</b>		<b>TOTAL FLOOR AREA.....</b>	
177 SQ.FT.		177 SQ.FT.	
4.5% OPENABLE FOR REQ. VENT. - OK!		9.0% FOR REQ. LIGHT - OK!	

**LIGHTING: (R303)**  
ALL ROOMS REQUIRE NATURAL LIGHT BY MEANS OF EXTERIOR WINDOWS OR SKYLIGHTS MIN. 8% OF THE FLOOR AREA OF THE ROOM.

**VENTILATION: (R303)**  
ALL ROOMS REQUIRE NATURAL VENTILATION BY MEANS OF OPENABLE WINDOWS MIN. 4% OF THE FLOOR AREA OF THE ROOM.

### ADU ROOF VENTILATION \*

ATTIC AREA TO BE VENTILATED - 705 SQ.FT.  
REQUIRED VENTILATION = 705 / 150 = 4.70 SQ.IN.  
4.70 x 144 = 676.80 SQ.IN.

GABLE VENT (12" x 18")  
NET FREE AREA EACH VENT = 216 SQ.IN.  
AMOUNT 676.80 / 216 = 3.13  
= USE 2 GABLE VENTS

WIRE EAVE VENT (3 1/2" x 14")  
NET FREE AREA EACH VENT = 49 SQ.IN.  
AMOUNT 676.80 / 49 = 13.81  
= USE 6 WIRE EAVE VENTS

\* COMBINATION OF GABLE VENTS AND/OR WIRED EAVE VENTS IS ALLOWED.

**ROOF VENTILATION: (R806.2)**  
THE NET FREE VENTILATING AREA OF ENCLOSED ATTICS AND ENCLOSED RAFTER SPACES SHALL NOT BE LESS THAN 1/150 OF THE AREA OF THE SPACE VENTILATED. EXCEPT THAT REDUCTION OF TOTAL AREA TO 1/300 IS PERMITTED PROVIDED THAT AT LEAST 50% AND NOT MORE THAN 80% OF THE REQUIRED VENTILATING AREA IS PROVIDED BY VENTILATORS LOCATED IN THE UPPER PORTION OF THE SPACE TO BE VENTILATED AT LEAST 3 FEET ABOVE THE AVE OR CORNICHE VENTS WITH THE BALANCE OF THE REQUIRED VENTILATION PROVIDED BY EAVE OR CORNICHE VENTS. AS AN ALTERNATIVE, THE NEW FREE CROSS-VENTILATION AREA MAY BE REDUCED TO 1/300 WHEN A CLASS I OR CLASS II VAPOR BARRIER IS INSTALLED ON THE WARM-IN-WINTER SIDE OF THE CEILING. A MINIMUM OF 1-INCH CLEARANCE SHALL BE PROVIDED BETWEEN THE INSULATION AND ROOF SHEATHING.

### SCHEDULES


KEY	DIMENSION	TYPE	DESCRIPTION	QTY
1	3'-0" x 6'-8"	EXT. SWING	SOLID CORE / WOOD	1
2	3'-0" x 6'-8" x 2	EXT. SWING FRENCH	SOLID CORE / WOOD	1
3	2'-6" x 6'-8"	INT. SWING	HOLLOW CORE INSULATED	2

KEY	SIZE	TYPE	DESCRIPTION / COLOR / SPEC	QTY
A	4'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	2
B	3'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	2
C	3'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	1
D	2'-0" x 1'-6"	SLIDING / DUAL PANE (GLAZED)	VINYL / WHITE / U-FACTOR = / SHGC =	1

KEY	NOTE
1	NEW EXTERIOR WALL 2x4 @ 16" STUDS W/ 5/8" GYP. BRD., 7/8" STUCCO, R-13 BATT. INSULATION
2	NEW INTERIOR WALL 2x4 @ 16" STUDS W/ 5/8" GYP. BRD., R-13 BATT. INSULATION
3	LINE OF ROOF EAVE
4	NEW DOOR OPENING W/ 1/2" MAX. THRESHOLD TYP. @ DOOR
5	NEW 2'-8" HIGH CABINET COUNTER WITH 4" BACK SPLASH, TYP.
6	BATHROOM CABINETS (PER SEPARATE PLAN)
7	SHELF AND HANGER ROD
8	MIRROR W/ MED. CAB
9	TEMPERED GLASS SHOWER DOOR

KEY	DESCRIPTION	COLOR / STYLE
1	SMOOTH STUCCO	'SWISS COFFEE' OR SIM.
2	WOOD TRIM	BROWN
3	ENTRY DOOR	WOOD
4	WINDOW	BLACK
5	LT WT CONCRETE TILE (5psf MAX.)	SPANISH RED
6	PATIO COVER (OPTIONAL)	'SWISS COFFEE' OR SIM.
7	EAVE VENTS (6) REQUIRED	
8	TANKLESS ELECT. WATER HEATER	
9	MINISPLIT CONDENSOR	
10	MINISPLIT UNIT	


ROOM	FLOOR	BASE	WALL	CEILING
ENTRY				
LIVING / DINING				
KITCHEN				
SLEEPING AREA				
BATHROOM				



- WINDOW NOTE:**
- GLAZING IN DOORS AND WINDOWS WITHIN 24" OF A DOOR SHALL BE SAFETY GLAZING (TEMPERED).
  - GLAZING IN WINDOWS WITHIN 18" OF THE FLOOR SHALL BE SAFETY GLAZING (TEMPERED GLASS).
  - EACH PANE OF SAFETY GLAZING INSTALLED IN HAZARDOUS LOCATIONS SHALL BE IDENTIFIED (ACID ETCHED, SAND BLASTED, CERAMIC FIRED, ETC.) BY A MANUFACTURER'S DESIGNATION, THE MANUFACTURER OR INSTALLER, AND THE SAFETY GLAZING STANDARD WHICH IT COMPLIES.
  - THE LOAD RESISTANCE OF THE GLASS UNDER UNIFORM LOAD IS DETERMINED IN ACCORDANCE WITH ASTM E1300.

# ELEVATIONS

1/4" = 1'-0"



970-546-2387  
lflbuilders.com

PROJECT  
PROJECT NAME  
PROJECT ADDRESS



**DISCLAIMER:**  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

- THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
- THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
- THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
- IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023


STYLE

DESCRIPTION  
**SPANISH STYLE FLOOR PLAN | ELEVATIONS | SCHEDULES**

SHEET  
**A1.0**

# FLOOR PLAN

1/4" = 1'-0"




REAR  
LEFT  
RIGHT  
ELEVATION  
SIDE VIEWS

- MINIMUM ROOM DIMENSIONS (R304 & R305)
- HABITABLE ROOMS SHALL HAVE A FLOOR AREA OF NOT LESS THAN 70 SF.
  - HABITABLE ROOMS SHALL NOT BE LESS THAN 7 FT. IN ANY HORIZONTAL DIMENSION.
  - HABITABLE SPACE AND HALLWAYS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 7 FT. BATHROOMS, TOILET ROOMS, AND LAUNDRY ROOMS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 6'-8".


### MINIMUM BATHROOM REQ.

NOTE:  
ULTRA LOW FLUSH (1.6 GALLONS MAX)  
TOILET REQ.  
(2016 CPC 402.2)

NOTE:  
SHOWER STALL TO BE  
1024 SQ.IN. MIN. INT.  
(2016 CPC 411.7)



### WINDOW EGRESS DETAIL



### ADU LIGHT & VENTILATION REQUIREMENTS

(N) ENTRY / LIVING ROOM / KITCHEN / DINING		LIGHT REQ.	
<b>VENTILATION REQ.</b>		<b>WINDOWS</b>	
1-4040.....	8.00 SQ.FT.	1-4040.....	16.00 SQ.FT.
2-3040.....	12.00 SQ.FT.	2-3040.....	24.00 SQ.FT.
1-3040.....	6.00 SQ.FT.	1-3040.....	12.00 SQ.FT.
<b>DOORS</b>		<b>DOORS (GLASS)</b>	
1-3068.....	20.00 SQ.FT.	1-2058.....	11.50 SQ.FT.
1-6068.....	40.00 SQ.FT.	1-4058.....	23.00 SQ.FT.
<b>TOTAL OPENABLE AREA.....86.00 SQ.FT.</b>		<b>TOTAL GLASS AREA.....86.50 SQ.FT.</b>	
<b>TOTAL FLOOR AREA.....343 SQ.FT.</b>		<b>TOTAL FLOOR AREA.....343 SQ.FT.</b>	
25.0% OPENABLE FOR REQ. VENT. - OK!		25.2% FOR REQ. LIGHT - OK!	

(N) BEDROOM 1		LIGHT REQ.	
<b>VENTILATION REQ.</b>		<b>WINDOW</b>	
1-4040.....	8.00 SQ.FT.	1-4040.....	16.00 SQ.FT.
<b>TOTAL OPENABLE AREA.....8.00 SQ.FT.</b>		<b>TOTAL OPENABLE AREA.....16.00 SQ.FT.</b>	
<b>TOTAL FLOOR AREA.....177 SQ.FT.</b>		<b>TOTAL FLOOR AREA.....177 SQ.FT.</b>	
4.5% OPENABLE FOR REQ. VENT. - OK!		9.0% FOR REQ. LIGHT - OK!	

LIGHTING: (R303)  
ALL ROOMS REQUIRE NATURAL LIGHT BY MEANS OF EXTERIOR WINDOWS OR SKYLIGHTS MIN. 8% OF THE FLOOR AREA OF THE ROOM.

VENTILATION: (R303)  
ALL ROOMS REQUIRE NATURAL VENTILATION BY MEANS OF OPENABLE WINDOWS MIN. 4% OF THE FLOOR AREA OF THE ROOM.

### ADU ROOF VENTILATION \*

ATTIC AREA TO BE VENTILATED - 705 SQ.FT.  
REQUIRED VENTILATION = 705 / 150 = 4.70 SQ.IN.  
4.70 x 144 = 676.80 SQ.IN.

GABLE VENT (12" x 18")  
NET FREE AREA EACH VENT = 216 SQ.IN.  
AMOUNT 676.80 / 216 = 3.13  
= USE 2 GABLE VENTS

WIRE EAVE VENT (3 1/2" x 14")  
NET FREE AREA EACH VENT = 49 SQ.IN.  
AMOUNT 676.80 / 49 = 13.81  
= USE 6 WIRE EAVE VENTS

\* COMBINATION OF GABLE VENTS AND/OR WIRED EAVE VENTS IS ALLOWED.

ROOF VENTILATION: (R806.2)  
THE NET FREE VENTILATING AREA OF ENCLOSED ATTICS AND ENCLOSED RAFTER SPACES SHALL NOT BE LESS THAN 1/150 OF THE AREA OF THE SPACE VENTILATED. EXCEPT THAT REDUCTION OF TOTAL THE AREA TO 1/300 IS PERMITTED PROVIDED THAT AT LEAST 50% AND NOT MORE THAN 80% OF THE REQUIRED VENTILATING AREA IS PROVIDED BY VENTILATORS LOCATED IN THE UPPER PORTION OF THE SPACE TO BE VENTILATED AT LEAST 3 FEET ABOVE THE AVE OR CORNICE VENTS WITH THE BALANCE OF THE REQUIRED VENTILATION PROVIDED BY EAVE OR CORNICE VENTS. AS AN ALTERNATIVE, THE NEW FREE CROSS-VENTILATION AREA MAY BE REDUCED TO 1/300 WHEN A CLASS I OR CLASS II VAPOR BARRIER IS INSTALLED ON THE WARM-IN-WINTER SIDE OF THE CEILING. A MINIMUM OF 1-INCH CLEARANCE SHALL BE PROVIDED BETWEEN THE INSULATION AND ROOF SHEATHING.

### SCHEDULES

KEY	DIMENSION	TYPE	DESCRIPTION	QTY
①	3'-0" x 6'-8"	EXT. SWING	SOLID CORE / WOOD	1
②	3'-0" x 6'-8" x2	EXT. SWING FRENCH	SOLID CORE / WOOD	1
③	2'-6" x 6'-8"	INT. SWING	HOLLOW CORE INSULATED	2


KEY	SIZE	TYPE	DESCRIPTION / COLOR / SPEC	QTY
A	4'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	2
B	3'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	2
C	3'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	1
D	2'-0" x 1'-6"	SLIDING / DUAL PANE (GLAZED)	VINYL / WHITE / U-FACTOR = / SHGC =	1

KEY	NOTE
①	NEW EXTERIOR WALL 2x6 @ 16" STUDS W/ 5/8" GYP. BRD., HARDIBOARD SHIPLAP, R-19 BATT. INSULATION
②	NEW INTERIOR WALL 2x4 @ 16" STUDS W/ 5/8" GYP. BRD., R-13 BATT. INSULATION
③	LINE OF ROOF EAVE
④	NEW DOOR OPENING W/ 1/2" MAX. THRESHOLD TYP. @ DOOR
⑤	NEW 2'-8" HIGH CABINET COUNTER WITH 4" BACK SPLASH, TYP.
⑥	BATHROOM CABINETS (PER SEPARATE PLAN)
⑦	SHELF AND HANGER ROD
⑧	MIRROR W/ MED. CAB
⑨	TEMPERED GLASS SHOWER DOOR


KEY	DESCRIPTION	COLOR / STYLE
①	HARDIBOARD SHIPLAP SIDING	WHITE OR OLIVE GREEN
②	WOOD TRIM	WHITE / OPEN END RAFTERS
③	ENTRY DOOR	WHITE
④	WINDOW	WHITE
⑤	30 YR. COMPOSITION SHINGLES	COLOR 'TBD' BY OWNER
⑥	PATIO COVER (OPTIONAL)	WHITE
⑦	EAVE VENTS (6) REQUIRED	-
⑧	TANKLESS ELECT. WATER HEATER	-
⑨	MINISPLIT CONDENSOR	-
⑩	MINISPLIT UNIT	-

ROOM	FLOOR	BASE	WALL	CEILING
ENTRY	CARPET	COVERED VINYL	5/8" GYP. BRD. / PAINTED	5/8" GYP. BRD. / ACCOUST.
LIVING / DINING	LINOLEUM	WOOD	5/8" GREEN BOARD	5/8" GYP. BRD. / PAINTED
KITCHEN	COMPOSITE FLOORING	TOP SET RUBBER ELASTOMERIC	STUCCO	5/8" GREEN BOARD
SLEEPING AREA	CERAMIC TILE		PLASTER	TILE
BATHROOM	CONCRETE		TILE	STUCCO
	TEX-O-DEK			

### DOORS




### WINDOWS



- WINDOW NOTE:**
- GLAZING IN DOORS AND WINDOWS WITHIN 24" OF A DOOR SHALL BE SAFETY GLAZING (TEMPERED).
  - GLAZING IN WINDOWS WITHIN 18" OF THE FLOOR SHALL BE SAFETY GLAZING (TEMPERED GLASS).
  - EACH PANE OF SAFETY GLAZING INSTALLED IN HAZARDOUS LOCATIONS SHALL BE IDENTIFIED (ACID ETCHED, SAND BLASTED, CERAMIC FIRED, ETC.) BY A MANUFACTURER'S DESIGNATION, THE MANUFACTURER OR INSTALLER, AND THE SAFETY GLAZING STANDARD WHICH IT COMPLIES.
  - THE LOAD RESISTANCE OF THE GLASS UNDER UNIFORM LOAD IS DETERMINED IN ACCORDANCE WITH ASTM E1300.

# ELEVATIONS

1/4" = 1'-0"



**ROOFING NOTE:**  
OWENS CORNING ASPHALT SHINGLE, WOODMOOR, CLASS A (ASTM E108, UL790), ICC-ES AC438, CLASS H UPLIFT (ASTM D7158) 150 MPH INSTALL WITH UNDERLAYMENT IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS. CONTRACTOR TO ORDER SAMPLE TO VERIFY THIS PRODUCT MATCHES THE EXISTING MAIN RESIDENCE ROOF COVERING COLOR AND VERIFY COLOR WITH HOMEOWNER.



PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

- THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
- THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
- THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
- IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023



STYLE

DESCRIPTION  
**CRAFTSMAN STYLE FLOOR PLAN | ELEVATIONS | SCHEDULES**

SHEET  
**A1.0**


# FLOOR PLAN

1/4" = 1'-0"




- MINIMUM ROOM DIMENSIONS (R304 & R305)**
- HABITABLE ROOMS SHALL HAVE A FLOOR AREA OF NOT LESS THAN 70 SF.
  - HABITABLE ROOMS SHALL NOT BE LESS THAN 7 FT. IN ANY HORIZONTAL DIMENSION.
  - HABITABLE SPACE AND HALLWAYS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 7 FT. BATHROOMS, TOILET ROOMS, AND LAUNDRY ROOMS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 6'-8".

### MINIMUM BATHROOM REQ.



### WINDOW EGRESS DETAIL



### ADU LIGHT & VENTILATION REQUIREMENTS

(N) ENTRY / LIVING ROOM / KITCHEN / DINING		LIGHT REQ.	
<b>VENTILATION REQ.</b>		<b>WINDOWS</b>	
1-4040.....	8.00 SQ.FT.	1-4040.....	16.00 SQ.FT.
2-3040.....	12.00 SQ.FT.	2-3040.....	24.00 SQ.FT.
1-3040.....	6.00 SQ.FT.	1-3040.....	12.00 SQ.FT.
<b>DOORS</b>		<b>DOORS (GLASS)</b>	
1-3068.....	20.00 SQ.FT.	1-2058.....	11.50 SQ.FT.
1-6068.....	40.00 SQ.FT.	1-4058.....	23.00 SQ.FT.
<b>TOTAL OPENABLE AREA.....86.00 SQ.FT.</b>		<b>TOTAL GLASS AREA.....86.50 SQ.FT.</b>	
<b>TOTAL FLOOR AREA.....343 SQ.FT.</b>		<b>TOTAL FLOOR AREA.....343 SQ.FT.</b>	
25.0% OPENABLE FOR REQ. VENT. - OK!		25.2% FOR REQ. LIGHT - OK!	

(N) BEDROOM 1		LIGHT REQ.	
<b>VENTILATION REQ.</b>		<b>WINDOW</b>	
1-4040.....	8.00 SQ.FT.	1-4040.....	16.00 SQ.FT.
<b>TOTAL OPENABLE AREA.....8.00 SQ.FT.</b>		<b>TOTAL OPENABLE AREA.....16.00 SQ.FT.</b>	
<b>TOTAL FLOOR AREA.....177 SQ.FT.</b>		<b>TOTAL FLOOR AREA.....177 SQ.FT.</b>	
4.5% OPENABLE FOR REQ. VENT. - OK!		9.0% FOR REQ. LIGHT - OK!	

**LIGHTING: (R303)**  
ALL ROOMS REQUIRE NATURAL LIGHT BY MEANS OF EXTERIOR WINDOWS OR SKYLIGHTS MIN. 8% OF THE FLOOR AREA OF THE ROOM.

**VENTILATION: (R303)**  
ALL ROOMS REQUIRE NATURAL VENTILATION BY MEANS OF OPENABLE WINDOWS MIN. 4% OF THE FLOOR AREA OF THE ROOM.

### ADU ROOF VENTILATION \*

ATTIC AREA TO BE VENTILATED - 705 SQ.FT.  
REQUIRED VENTILATION = 705 / 150 = 4.70 SQ.IN.  
4.70 x 144 = 676.80 SQ.IN.  
GABLE VENT (12" x 18")  
NET FREE AREA EACH VENT = 216 SQ.IN.  
AMOUNT 676.80 / 216 = 3.13  
= USE 2 GABLE VENTS

WIRE EAVE VENT (3 1/2" x 14")  
NET FREE AREA EACH VENT = 49 SQ.IN.  
AMOUNT 676.80 / 49 = 13.81  
= USE 6 WIRE EAVE VENTS

\* COMBINATION OF GABLE VENTS AND/OR WIRED EAVE VENTS IS ALLOWED.

**ROOF VENTILATION: (R606.2)**  
THE NET FREE VENTILATING AREA OF ENCLOSED ATTICS AND ENCLOSED RAFTER SPACES SHALL NOT BE LESS THAN 1/150 OF THE AREA OF THE SPACE VENTILATED. EXCEPT THAT REDUCTION OF TOTAL THE AREA TO 1/300 IS PERMITTED PROVIDED THAT AT LEAST 50% AND NOT MORE THAN 80% OF THE REQUIRED VENTILATING AREA IS PROVIDED BY VENTILATORS LOCATED IN THE UPPER PORTION OF THE SPACE TO BE VENTILATED AT LEAST 3 FEET ABOVE THE AVE OR CORNICE VENTS WITH THE BALANCE OF THE REQUIRED VENTILATION PROVIDED BY EAVE OR CORNICE VENTS. AS AN ALTERNATIVE, THE NEW FREE CROSS-VENTILATION AREA MAY BE REDUCED TO 1/300 WHEN A CLASS I OR CLASS II VAPOR BARRIER IS INSTALLED ON THE WARM-IN-WINTER SIDE OF THE CEILING. A MINIMUM OF 1-INCH CLEARANCE SHALL BE PROVIDED BETWEEN THE INSULATION AND ROOF SHEATHING.

### SCHEDULES



KEY	DIMENSION	TYPE	DESCRIPTION	QTY
1	3'-0" x 6'-8"	EXT. SWING	SOLID CORE / WOOD	1
2	3'-0" x 6'-8" x 2	EXT. SWING FRENCH	SOLID CORE / WOOD	1
3	2'-6" x 6'-8"	INT. SWING	HOLLOW CORE INSULATED	2

KEY	SIZE	TYPE	DESCRIPTION / COLOR / SPEC	QTY
A	4'-0" x 4'-0"	SLIDING / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	2
B	3'-0" x 4'-0"	SINGLE HUNG / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	2
C	3'-0" x 4'-0"	SLIDING / DUAL PANE	VINYL / WHITE / U-FACTOR = / SHGC =	1
D	2'-0" x 1'-6"	SLIDING / DUAL PANE (GLAZED)	VINYL / WHITE / U-FACTOR = / SHGC =	1

KEY	NOTE
1	NEW EXTERIOR WALL 2x4 @ 16" STUDS W/ 5/8" GYP. BRD., 7/8" STUCCO, R-13 BATT. INSULATION
2	NEW INTERIOR WALL 2x4 @ 16" STUDS W/ 5/8" GYP. BRD., R-13 BATT. INSULATION
3	LINE OF ROOF EAVE
4	NEW DOOR OPENING W/ 1/2" MAX. THRESHOLD TYP. @ DOOR
5	NEW 2'-8" HIGH CABINET COUNTER WITH 4" BACK SPLASH, TYP.
6	BATHROOM CABINETS (PER SEPARATE PLAN)
7	SHELF AND HANGER ROD
8	MIRROR W/ MED. CAB
9	TEMPERED GLASS SHOWER DOOR


KEY	DESCRIPTION	COLOR / STYLE
1	STUCCO	TBD BY OWNER
2	WOOD TRIM	TBD BY OWNER
3	ENTRY DOOR	WOOD
4	WINDOW	WHITE
5	COMPOSITION ROOFING	COLOR TBD BY OWNER
6	PATIO COVER (OPTIONAL)	WHITE
7	EAVE VENTS (6) REQUIRED	
8	TANKLESS ELECT. WATER HEATER	
9	MINISPLIT CONDENSOR	
10	MINISPLIT UNIT	

ROOM	FLOOR	BASE	WALL	CEILING
ENTRY	CARPET	COVERED VINYL	5/8" GYP. BRD. / PAINTED	5/8" GYP. BRD. / ACCOUST.
LIVING / DINING	LINOLEUM	WOOD	5/8" GREEN BOARD	5/8" GYP. BRD. / PAINTED
KITCHEN	COMPOSITE FLOORING	TOP SET RUBBER ELASTOMERIC	STUCCO	5/8" GREEN BOARD
SLEEPING AREA	CERAMIC TILE		PLASTER	TILE
BATHROOM	CONCRETE		TILE	STUCCO
	TEX-O-DEK			



# ELEVATIONS

1/4" = 1'-0"



**ROOFING NOTE:**  
OWENS CORNING ASPHALT SHINGLE, WOODMOOR, CLASS A (ASTM E108, UL790), ICC-ES AC438, CLASS H UPLIFT (ASTM D7158) 150 MPH INSTALL WITH UNDERLAYMENT IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS. CONTRACTOR TO ORDER SAMPLE TO VERIFY THIS PRODUCT MATCHES THE EXISTING MAIN RESIDENCE ROOF COVERING COLOR AND VERIFY COLOR WITH HOMEOWNER.

- WINDOW NOTE:**
- GLAZING IN DOORS AND WINDOWS WITHIN 24" OF A DOOR SHALL BE SAFETY GLAZING (TEMPERED).
  - GLAZING IN WINDOWS WITHIN 18" OF THE FLOOR SHALL BE SAFETY GLAZING (TEMPERED GLASS).
  - EACH PANE OF SAFETY GLAZING INSTALLED IN HAZARDOUS LOCATIONS SHALL BE IDENTIFIED (ACID ETCHED, SAND BLASTED, CERAMIC FIRED, ETC.) BY A MANUFACTURER'S DESIGNATION, THE MANUFACTURER OR INSTALLER, AND THE SAFETY GLAZING STANDARD WHICH IT COMPLIES.
  - THE LOAD RESISTANCE OF THE GLASS UNDER UNIFORM LOAD IS DETERMINED IN ACCORDANCE WITH ASTM E1300.



PROJECT  
PROJECT NAME  
PROJECT ADDRESS



**DISCLAIMER:**  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

- THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
- THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
- THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
- IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
**TRADITIONAL STYLE FLOOR PLAN | ELEVATIONS | SCHEDULES**

SHEET  
**A1.0**

**TYPICAL UTILITY NOTES**

**CALIFORNIA PLUMBING CODE**

- THE SEWER/DRAIN LINE FOR THE APPROVED ADU MUST BE LOCATED ON THE LOT IT SERVES AND CONNECTED TO THE PROPERTY'S MAIN LATERAL SEWER/DRAIN LINE PRIOR TO THE MAIN SEWER/DRAIN LINE CONNECTION TO THE EXISTING MAIN RESIDENCE.**
- NEW FIXTURES SHALL MEET THE FOLLOWING WATER CONSERVATION PROVISIONS:
  - SHOWER HEADS 1.8 GPM @ 80 PSI
  - LAVATORY FAUCETS 1.2 GPM @ 60 PSI MAXIMUM  
0.8 GPM @ 20 PSI MINIMUM
  - KITCHEN FAUCETS 1.8 GPM @ 60 PSI
  - WATER CLOSETS 1.28 GAL/FLUSH
- SHOWER DOORS SHALL BE TEMPERED GLASS AND SWING OUT.
- ALL HOSE BIBS MUST BE PROTECTED BY AN ANTI SIPHON DEVICE.
- ANTI-SCALDING OR THERMOSTATIC MIXING VALVES ARE REQUIRED AT SHOWERS AND TUB/SHOWER COMBINATIONS.
- WATER PIPING MATERIALS WITHIN A BUILDING SHALL BE IN ACCORDANCE WITH CPC SECTION 604.1.2 OF THE CALIFORNIA PLUMBING CODE. PEX, CPVC AND OTHER PLASTIC WATER PIPING SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION 604.1.2 OF THE CPC, INSTALLATION STANDARDS OF APPENDIX I OF THE CPC AND MANUFACTURERS RECOMMENDED INSTALLATION STANDARDS. CPVC WATER PIPING REQUIRES A CERTIFICATION OF COMPLIANCE AS SPECIFIED IN SEC 604.1.1 OF THE CPC PRIOR TO PERMIT ISSUANCE.
- WATER HEATERS SHALL HAVE A TEMPERATURE AND PRESSURE RELIEF VALVE. THE POINT OF DISCHARGE FOR RELIEF VALVE SHALL BE IN ACCORDANCE WITH CPC SECTION 608.7.

**CALIFORNIA MECHANICAL CODE**

- A DOMESTIC CLOTHES DRYER DUCT SHALL BE OF METAL AND A MINIMUM OF 4" IN DIAMETER. THE EXHAUST DUCT SHALL NOT EXCEED A TOTAL COMBINED HORIZONTAL AND VERTICAL LENGTH OF 14', INCLUDING TWO 90-DEGREE ELBOWS. TWO FEET SHALL BE DEDUCTED FOR EACH 90-DEGREE ELBOW IN EXCESS OF TWO. **THE DRYER SHALL BE VENTED TO THE OUTSIDE AIR.**
- A DRYER COMPARTMENT/CLOSET SHALL BE PROVIDED WITH A MINIMUM OPENING OF 100 SQUARE INCHES FOR MAKEUP AIR IN THE DOOR OR BY OTHER APPROVED MEANS.
- CONDENSATE LINES FROM MECHANICAL EQUIPMENT SHALL DISCHARGE TO A PLUMBING FIXTURE OR STORM DRAIN BY MEANS OF AN INDIRECT WASTE PIPE. CONDENSATE LINES SHALL NOT TERMINATE IN LANDSCAPE OR YARD AREAS.
- WHEN APPROVED, THE ENGINEER OF RECORD, ARCHITECT OR PLANS PREPARER SHALL PROVIDE MANUFACTURER'S DETAILS AND SPECIFICATIONS FOR VENTING OF TANKLESS WATER HEATERS.

**CALIFORNIA ELECTRICAL CODE**

- THE ENGINEER OF RECORD, ARCHITECT OR PLANS PREPARER SHALL PROVIDE DETAILS TO THE CITY INSPECTOR, UPON REQUEST, SHOWING THE LOCATION AND SIZE OF THE MAIN SERVICE PANEL (MSP) AND THE SOURCE OF POWER FOR THE APPROVED ADU.
- SMOKE ALARMS SHALL BE INSTALLED AT THE FOLLOWING LOCATIONS:
  - OUTSIDE EACH SEPARATE SLEEPING AREA IN THE IMMEDIATE VICINITY OF BEDROOMS.
  - IN EACH ROOM USED FOR SLEEPING PURPOSES.
  - SMOKE ALARMS SHALL BE INTERCONNECTED SUCH THAT THE ACTUATION OF ONE SMOKE ALARM ACTIVATES ALL ALARMS.
  - SMOKE ALARMS SHALL RECEIVE THEIR PRIMARY POWER FROM THE BUILDING'S WIRING WITH BATTERY BACKUP.
  - APPROVED COMBINED SMOKE ALARMS AND CARBON MONOXIDE ALARMS ARE ACCEPTABLE.

APPROVED CARBON MONOXIDE ALARMS SHALL BE INSTALLED IN DWELLING UNITS AND IN SLEEPING UNITS AT THE FOLLOWING LOCATIONS:

- CARBON MONOXIDE ALARMS SHALL RECEIVE THEIR PRIMARY POWER FROM THE BUILDING'S WIRING WITH BATTERY BACKUP.
  - CARBON MONOXIDE ALARMS SHALL BE INTERCONNECTED SUCH THAT THE ACTUATION OF ONE CO ALARM ACTIVATES ALL CO ALARMS.
  - LOCATE CARBON MONOXIDE ALARMS OUTSIDE EACH SLEEPING AREA IN THE IMMEDIATE VICINITY OF THE BEDROOMS.
  - LOCATED CARBON MONOXIDE ALARMS ON EVERY LEVEL OF A DWELLING UNIT.
  - APPROVED COMBINED SMOKE ALARMS AND CARBON MONOXIDE ALARMS ARE ACCEPTABLE.
- RECEPTACLES WILL BE PROVIDED AROUND THE PERIMETER OF HABITABLE ROOMS SO THAT A RECEPTACLE IS LOCATED WITHIN 6 FEET FROM ANY POINT ALONG THE WALL, INCLUDING ONE ON WALLS 2 FEET AND WIDER.
  - ALL KITCHEN AND DINING AREA COUNTERS RECEPTACLES SHALL BE INSTALLED AT ALL COUNTER SPACES 12 INCHES OR WIDER, LOCATED SO THAT NO POINT, MEASURED ALONG THE WALL, IS MORE THAN 24 INCHES FROM A RECEPTACLE. RECEPTACLES SERVING ISLANDS OR PENINSULAS COUNTERS SHALL BE ABOVE OR WITHIN 12 INCHES BELOW THE TOP AND LOCATED SO THAT NO POINT IS MORE THAN 24 INCHES FROM AN OUTLET.
  - A RECEPTACLE SHALL BE INSTALLED IN HALLWAYS MORE THAN 10 FEET IN LENGTH.
  - AT LEAST ONE WALL SWITCH-CONTROLLED LIGHTING OUTLET (FIXTURE) SHALL BE INSTALLED IN EVERY HABITABLE ROOM, BATHROOM AND HALLWAY WITH ELECTRICAL POWER, AND AT ALL EXTERIOR DOORS.
  - RECEPTACLES SHALL BE INSTALLED IN THE FRONT AND REAR YARDS OF THE DWELLING AND SHALL BE PROTECTED WITH A GFCI AND WATERPROOF.
  - ALL RECEPTACLES IN/NEAR BATHROOM, OUTDOORS, KITCHEN (WHERE RECEPTACLES SERVE COUNTER TOP SURFACES), SINKS, BATHTUBS AND LAUNDRY AREAS SHALL HAVE GROUND-FAULT CIRCUIT-INTERRUPTER (GFCI) PROTECTION.
  - ALL BRANCH CIRCUITS SUPPLYING RECEPTACLES IN KITCHENS, FAMILY ROOMS, DINING ROOMS, LIVING ROOMS, PARLORS, LIBRARIES, DENS, BEDROOMS, SUNROOMS, RECREATION ROOMS, CLOSETS, HALLWAYS AND SIMILAR ROOMS OR AREAS SHALL BE PROTECTED BY A LISTED ARC-FAULT CIRCUIT INTERRUPTER (AFCI).
  - IN EVERY DWELLING UNIT, FIXED APPLIANCES SUCH AS FOOD WASTE GRINDERS, DISHWASHERS, WASHING MACHINES, DRYERS, LAUNDRY TRAY LOCATIONS, BUILT-IN REFRIGERATORS OR FREEZERS, FURNACES, AC UNITS, BUILT-IN HEATERS OR ANY OTHER FIXED APPLIANCE WITH A MOTOR OF 1/4 H.P. OR LARGER SHALL BE ON A SEPARATE 20 AMP. BRANCH CIRCUIT.

- RECEPTACLES SHALL BE LISTED AS TAMPER-RESISTANT FOR ALL 15 AND 20 AMPERE RECEPTACLES IN DWELLING UNIT FAMILY, DINING, LIVING, PARLORS, LIBRARIES, DENS, BEDROOMS, SUNROOMS, RECREATION ROOMS, CLOSETS, HALLWAYS, OR SIMILAR ROOMS AND AREAS.
- 120-VOLT RECEPTACLE SHALL BE LOCATED WITHIN 25' OF THE EQUIPMENT FOR SERVICE AND MAINTENANCE PURPOSES.
- AN APPROVED INDEPENDENT ELECTRICAL DISCONNECT IS REQUIRED FOR EACH PIECE OF EQUIPMENT WITHIN SIGHT OF THE EQUIPMENT, WHEN SUPPLY VOLTAGE IS GREATER THAN 50 VOLTS.
- THE KITCHEN SHALL BE PROVIDED WITH A MINIMUM OF TWO OR MORE 20AMP SMALL APPLIANCE BRANCH CIRCUITS.
- LAUNDRY AREAS SHALL BE PROVIDED WITH AT LEAST ONE 20AMP BRANCH CIRCUIT.
- BATHROOMS SHALL BE PROVIDED WITH ONE OR MORE 20AMP BRANCH CIRCUITS.
- LIGHTING CONTROL FOR BEDROOMS, FAMILY ROOM, OFFICE, GAME ROOM, AND KITCHEN TO BE ON DIMMERS.
- LIGHTING CONTROL FOR BATHROOMS TO BE ON VACANCY SENSORS.
- ALL EXTERIOR LIGHTING TO BE CONTROLLED BY PHOTO SENSOR TO TURN OFF WITH SUNLIGHT OR TIMER.
- CONDUCTORS NORMALLY USED TO CARRY CURRENT SHALL BE OF COPPER.
- PROVIDE UFER OR OTHER APPROVED GROUND PER CEC SECTION 250-50.
- OUTDOOR LIGHTING SHALL BE PROVIDED AT EACH EXTERIOR DOOR.
- A WORK LIGHT, SWITCH, AND RECEPTACLE OUTLET IS REQUIRED FOR ATTICS, WHERE THE SPACE IS USED FOR STORAGE OR CONTAIN EQUIPMENT REQUIRING SERVICING. THE LIGHTING OUTLET SHALL BE PROVIDED AT OR NEAR THE EQUIPMENT REQUIRING SERVICING.

**CALIFORNIA ENERGY CODE COMMENTS**


- RECESSED LIGHTS INSTALLED IN AN INSULATED CEILING OR CAVITY ARE REQUIRED TO HAVE A ZERO CLEARANCE INSULATION COVER (IC), BE ASTM E 283 CERTIFIED THAT THEY ARE AIR TIGHT, AND SEALED WITH A GASKET OR CAULK BETWEEN THE HOUSING AND THE CEILING.
- OUTDOOR LIGHTING ATTACHED TO A BUILDING MUST BE HIGH EFFICACY, OR CONTROLLED BY A MOTION SENSOR WITH AN INTEGRAL PHOTO-CONTROL.
- ALL NEW GLAZING SHALL BE INSTALLED WITH LABELS TO REMAIN IN PLACE FOR INSPECTION.
- ROOMS CONTAINING A SHOWER SHALL BE MECHANICALLY VENTILATED. A MINIMUM RATE OF 50CFM IS REQUIRED. UPON REQUEST FROM THE CITY INSPECTOR, THE ENGINEER OF RECORD, ARCHITECT OR PLANS PREPARER SHALL PROVIDE DETAILS FOR DUCTING SIZE AND LENGTHS TO MEET THE MINIMUM REQUIREMENTS OF ASHRA STANDARD 62.2 AND MAXIMUM SOUND RATING OR 3 SONE FOR INTERMITTENT OPERATION.
- THE 2022 CGBSC MANDATORY MEASURES ARE APPLICABLE TO THIS PROJECT.
- SHOW ON THE FINAL PLANS THE CODE-REQUIRED SOLAR VOLTAIC SYSTEM CITED IN CENC SECTION150.1(C)14.

**CALIFORNIA GREEN BUILDING STANDARDS CODE**

- THE CODE-REQUIRED EV CHARGING CONDUIT AND CONDUCTORS CITED IN THE CGBSC SECTION 4106.4.1 ARE APPLICABLE TO THIS PROJECT.

**UTILITY LAYOUT**

1/4" = 1'-0"



**UTILITY LEGEND**

- |  |                               |  |   |
|--|-------------------------------|--|---|
|  | NEW WALL                      |  | HOT / COLD WATER  |
|  | DOUBLE SWITCH                 |  | COLD WATER  |
|  | SINGLE SWITCH                 |  | BATTERY OPER. SMOKE DETECT.   |
|  | ELECTRICAL PANEL / METER      |  | CARBON DETECT.  |
|  | GAS METER                     |  | HARD WIRE SMOKE DETECT. W/ BATT                                     |
|  | WALL FURNACE                  |  | MECH. VENT/5 AIR CHANGE   |
|  | DUPLEX OUTLET @ 15' F.F.      |  | CHIME   |
|  | GROUND FAULT INT. OUTLET      |  | TELEPHONE OUTLET  |
|  | SINGLE SWITCH W/ POWER OUTLET |  | DOOR BELL   |
|  | OUTLET AT 3'-6" F.F.F.        |  | TANKLESS (INSTANTANEOUS) WATER HEATER<br>INSTALLED ON EXTERIOR WALL |
|  | RECESSED LIGHT                |  | AC CONDENSER  |
|  | CEILING MOUNTED LIGHT         |  | AC CONDENSER DISCONNECT   |
|  | WALL MOUNTED LIGHT            |  | MINI-SPLIT UNIT   |
|  | THERMOSTAT                    |  | MINI-SPLIT CONDENSER  |
|  | T.V. ANTENNA / CABLE OUTLET   |  | ELECTRICAL METER  |



PROJECT  
PROJECT NAME  
PROJECT ADDRESS




DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR; THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023


STYLE

DESCRIPTION  
**UTILITY LAYOUT PLAN & NOTES**


SHEET  
**UT-1**



SEWER TYPICAL ON LOT  
N.T.S.




DETAIL 1



DETAIL 2

CONSTRUCT 3.14kw (MIN.)  
PV SOLAR PANEL SYSTEM PER CF1R TITLE 24  
REQUIREMENTS CENC, EQUATEION 150.1-C


OVERHEAD SERVICE DROP  
CONDUCTORS CLEARANCES  
ABOVE ROOFS AND  
GROUND (SEE CBC SEC.  
230-24)



3 WIRE, 1 Ø AMP RATING OF SERVICE	SIZE OF SERVICE ENTRANCE CONDUCTOR (THW)		STEEL RIGID GALVANIZED CONDUIT SIZE FOR OVERHEAD SERVICE			GROUNDING ELECTRODE CONDUCTOR	
	COPPER	ALUMINUM	CU COND.	AL COND.	MAX. HT.		
100	#4	#2	1 ¼"	1 ¼"	30"	#8	#6
125	#2	1/0	1 ¼"	1 ½"	40"	#8	#6
150	#1	2/0	1 ¼"	1 ½"	40"	#6	#4
175	1/0	3/0	1 ½"	2"	60"	#6	#4
200	2/0	4/0	1 ½"	2"	60"	#4	#2

MINIMUM 100 AMP RESIDENTIAL SERVICE. ALL ELECTRICAL EQUIPMENT SHALL BE LISTED BY AN APPROVED TESTING AGENCY.

ELECTRICAL SERVICE PANEL DETAIL



SOLAR SYSTEM LAYOUT  
N.T.S.



970-546-2387  
lfbuilders.com

PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR; THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023


STYLE

DESCRIPTION  
UTILITY DETAILS

SHEET  
UT-2


# ROOF FRAMING PLAN

1/4" = 1'-0"




# FOUNDATION PLAN

1/4" = 1'-0"




# SECTION 1-1

1/4" = 1'-0"



# SECTION 2-2

1/4" = 1'-0"



# ROOF SHEATHING

5/8" CDX PLYWOOD (P1=24/0) 5 PLY W/ 10d @ 6" O.C. BOUNDARIES EDGES & 12" O.C. FIELD - LAY PER PERPENDICULAR TO FRAMING, SEE: 3/SD1

# SHEAR WALL SCHEDULE

WALL MATERIAL	SILL ANCHOR	SIMPSON HOLDDOWN	HORIZONTAL STRAP
5/8" DF CD-X PLYWOOD (P1=24/0, 5 PLY) W/10D AT 6"	3/4" @ 4' O.C.	SEE PLANS WHERE OCCURS	SEE 20/SD3

- ALL PANELS EDGES BACKED WITH NOMINAL FRAMING OR BLOCKING. PLYWOOD MAY BE INSTALLED EITHER HORIZONTALLY OR VERTICALLY. HOLDDOWNS NOTED ON PLANS SHALL BE PLACED AT END STUD OR END POST OF PANEL. NAILS SHALL BE COMMON NAILS.
- ALL EXTERIOR WALL SHALL BE COVERED WITH STRUCTURAL SHEATHING AS INDICATED IN TABLE ABOVE. SEE 3/SD-1 AND 20/SD3

# FASTENING SCHEDULE [TABLE R602.3(1)]

JOIST TO SILL OR GIRDER, TOENAIL.....	3-8d
BRIDGING TO JOIST OR STUD, TOENAIL EACH END.....	2-8d
2" SUBFLOOR TO JOIST OR GIRDER, BLIND AND FACE NAIL.....	2-16d
SOLE PLATE TO JOIST OR BLOCKING, TYP. FACE NAIL.....	16d @ 16" O.C.
SOLE PLATE TO JOIST OR BLOCKING, AT BRACED WALL PANELS.....	3-16d PER 16" O.C.
TOP PLATE TO STUD, END NAIL.....	2-16d
4-8D TOENAIL OR DOUBLE STUDS, FACE NAIL.....	2-16D END NAIL
DOUBLED TOP PLATES, TYPICAL FACE NAIL.....	16D @ 24" O.C.
DOUBLED TOP PLATES, LAP SPICE.....	16D @ 16" O.C.
TOP PLATES, LAPS AND INTERSECTIONS, FACE NAIL.....	8-16D
RIM JOIST TO TOP PLATE, TOENAIL.....	2-16D
BLOCKING BETWEEN JOISTS OR RAFTERS TO TOP PLATE, TOENAIL.....	8D @ 6" O.C.
CEILING JOISTS TO PLATE, TOENAIL.....	3-8D
CONTINUOUS HEADER TO STUD, TOENAIL.....	3-8D
CEILING JOISTS, LAPS OVER PARTITIONS, FACE NAIL.....	4-8D
CEILING JOISTS TO PARALLEL RAFTERS, FACE NAIL.....	3-16D
RAFTER TO PLATE, TOENAIL.....	3-16D
BUILT-UP CORNER STUDS.....	3-8D
BUILT-UP BEAMS.....	16D @ 24" O.C.
	16D @ 24" O.C. AT TOP AND BTM STAGGERD

OPENING SIZE	EXTERIOR WALLS & ALL INTERIOR BEARING WALLS	INTERIOR NON-BEARING WALLS
< 4'-0"	4 X 6 OR 6 X 4	4 X 4 OR 4 X 6 FLAT
< 6'-0"	4 X 10 OR 6 X 6	4 X 6 OR 6 X 6
< 8'-0"	3 1/2 X 9 1/4 SCL OR 6 X 8	4 X 8 OR 6 X 8

- FRAMING NOTES**
- CONTRACTOR TO VERIFY ALL DIMENSIONS AND CONDITIONS PRIOR TO START OF WORK AND NOTIFY ENGINEER OF ANY DISCREPANCIES IMMEDIATELY.
  - ALL HEADERS 6x4 U.O.N. @ EXTERIOR WALLS  
4x4 U.O.M. @ INTERIOR WALLS  
HEADER DETAIL SEE: 5 / SD1
  - TOP PLATE SPLICE DETAIL SEE: 6 / SD1
  - ROOF DIAPHRAGM NAILING TO BE INSPECTED BEFORE COVERING. FACE DOWN GRAIN OF PLYWOOD SHALL BE PERPENDICULAR TO SUPPORTS.
  - ALL DIAPHRAGM AND SHEAR WALL NAILING SHALL UTILIZE COMMON NAIL OR GALVANIZED BOX.
  - WALL SHEATHING TO BE 5/8" CDX (P1=24/0, 3 PLY) AT ALL EXTERIOR WALLS, FULL LENGTH
  - SIDING TO BE HARDIBOARD (OPTIONAL- 3 COAT STUCCO)
  - DRYWALL TO BE 5/8" THROUGHOUT
  - ALL BOLT HOLES SHALL BE DRILLED 1/32" TO 1/16" OVERSIZED.
  - CEILING MIN. 9' HIGH
  - WALLS ARE 2x6 STUDS AT EXTERIOR WALLS  
2x4 STUDS @ INTERIOR WALLS, EXCEPT 2x6 @ PLUMBING WALLS
  - ROOF MATERIAL: CDX PLYWOOD (P1=24/0, 5 PLY) W/10D @ 6", 6", & 12 O.C. (3X BLK'G @ EDGES) AND 30 YR COMP OVER 15 # FELT.
  - DENOTES ROOF RAFTERS OR ROOF TRUSSES
  - DENOTES CEILING JOIST.
  - ⊗ DENOTES POST SIZE 4"X MIN. U.N.O.
  - INDICATES SHEAR WALL W/ MIN. WALL LENGTH.
  - PROVIDE 2- 2X STUDS UNDER ALL BEAM ENDS WHERE NO POST IS CALLED FOR.
  - ALL LUMBER GRADES NOTED ON SPECIFIC MEMBERS (SEE ROOF FRAMING PLAN)
  - MINIMUM CONCRETE STRENGTH: 2500 PSI

- GENERAL NOTES**
- ALL HEADERS 6x4 U.O.N. @ EXTERIOR WALLS & 4x4 HEADERS @ INTERIOR WALLS U.N.O.
  - CLASS A ROOF COMPOSITION SHINGLES
  - 5/8" DRYWALL THROUGHOUT
  - HARDIBOARD SIDING (OPTIONAL - 3 COAT STUCCO)
  - 5/8" CDX ROOF SHEATHING
  - ALL EXTERIOR WALL STO BE COVERED WITH 5/8" CDX PLYWOOD (P1=24/0, 3 PLY) WITH 10d @ 6" O.C. EDGE, 12" O.C. FIELD
  - 2x6 STUDS @ EXTERIOR WALLS, 2x4 @ INTERIOR WALLS, EXCEPT 2x6 STUDS @ PLUMBING WALLS



PROJECT  
PROJECT NAME  
PROJECT ADDRESS



**DISCLAIMER:**  
THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
**ROOF FRAMING PLAN | FOUNDATION PLAN | SECTIONS**

SHEET  
**S1**

## MINIMUM CONSTRUCTION REQUIREMENTS

### GENERAL NOTES

1. THE CONTRACTOR/HOMEOWNER SHALL BE FULLY RESPONSIBLE FOR METHODS OF CONSTRUCTION, WORKMANSHIP, AND JOB SAFETY. WORKMANSHIP AND MATERIALS, INCLUDING FALSEWORK, BRACINGS, AND OTHER TEMPORARY ITEMS SHALL CONFORM TO THE GOVERNING CODES AND JOB SAFETY REQUIREMENTS PER OSHA STANDARDS.
2. CONSTRUCTION SAFETY PROVISIONS IN ACCORDANCE WITH THE BUILDING CODE SHALL BE PROVIDED AND APPROVED BY THE BUILDING INSPECTOR PRIOR TO STARTING ANY WORK ON THE BUILDING. PERMITS FOR PROTECTIVE FENCES AND FOR CANOPIES CONSTRUCTED ON PUBLIC PROPERTY MUST BE SECURED FROM THE DEPARTMENT OF BUILDING AND SAFETY.
3. CONSTRUCTION, INSPECTION AND PHYSICAL TESTING PROCEDURES SHALL CONFORM TO THE REQUIREMENTS OF THE GOVERNING CODES AND THE AMENDMENTS BY THE LOCAL JURISDICTION.
4. CONSTRUCTION LOADING SHALL NOT EXCEED THE DESIGN LIVE LOAD UNLESS SPECIAL, SHORING IS PROVIDED. ALLOWABLE LOADS SHALL BE REDUCED IN AREAS WHERE THE STRUCTURE HAS NOT ATTAINED ITS FULL DESIGN STRENGTH.
5. THE CONTRACTOR/HOMEOWNER SHALL PROVIDE A LEVEL TOP SURFACE FOR ALL SLABS IN ACCORDANCE WITH THE LEVELNESS TOLERANCE REQUIRED FOR ALL FINISHES, PARTITIONS, BUILT-IN CABINETS AND COUNTERS, ETC. THE CONTRACTOR SHALL ADJUST ALL BEAM SIDE FORMS TO ALLOW FOR AS-DELIVERED CAMBERS OF STEEL MEMBERS AND TO MAINTAIN THE MINIMUM DEPTH OF CONCRETE SLAB/TOPPING AT MIDSPAN OF THE STEEL MEMBERS.
6. PROVIDE NON-SLIP FINISH ON ALL CONCRETE STAIR TREADS, EXPOSED FLATWORK, AND WHERE SPECIFIED ON WORKING DRAWINGS.
7. ANY SUPPORT SERVICES PERFORMED BY THE ENGINEER DURING CONSTRUCTION SHALL BE DISTINGUISHED FROM CONTINUOUS AND DETAILED INSPECTION SERVICES WHICH ARE FURNISHED BY OTHERS. THESE SUPPORT SERVICES WHICH ARE FURNISHED BY THE ENGINEER, WHETHER OF MATERIAL OR WORK, AND WHETHER PERFORMED PRIOR TO, DURING OR AFTER COMPLETION OF CONSTRUCTION, ARE PERFORMED SOLELY FOR THE PURPOSE OF ASSISTING IN QUALITY CONTROL AND IN ACHIEVING CONFORMANCE WITH CONTRACT DRAWINGS AND SPECIFICATIONS, BUT THEY DO NOT GUARANTEE CONTRACTOR'S PERFORMANCE AND SHALL NOT BE CONSTRUED AS SUPERVISION OF CONSTRUCTION.
8. WHERE PUBIC UTILITY LINES OR EQUIPMENT MUST BE REMOVED AND RELOCATED, OBTAIN THE NECESSARY APPROVALS PRIOR TO STARTING CONSTRUCTION FROM THE RESPECTIVE UTILITY AGENCIES.
9. CONTROL JOINTS SHALL BE INSTALLED IN SLAB-ON-GRADES SO THE SLAB'S LENGTH-TO-WIDTH RATIO IS NOT MORE THAN 1.25:1. CONTROL JOINTS SHALL BE COMPLETED WITHIN 12 HOURS OF CONCRETE PLACEMENT AND THE JOINT DEPTH SHALL BE 1/4 THE SLAB THICKNESS.
10. ALL TEMPORARY SHORING SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR/HOMEOWNER, UNLESS SPECIFICALLY NOTED OTHERWISE ON THE PLANS. CONTRACTOR SHALL PROVIDE A COPY OF SHORING PLANS TO THE ENGINEER PRIOR TO INSTALLATION.

### GOVERNING CODES:

1. THE DESIGN COMPLIES TO THE 2022 CALIFORNIA RESIDENTIAL CODE (CRC), THE 2022 CALIFORNIA BUILDING CODE (CBC), 2022 CALIFORNIA PLUMBING CODE (CPC), 2022 CALIFORNIA MECHANICAL CODE (CMC), 2022 CALIFORNIA ELECTRICAL CODE (CEC) AND THE 2022 CALIFORNIA ENERGY CODE (CENC) AND WITH AMENDMENTS MADE BY THE LOCAL JURISDICTION.
2. CONSTRUCTION IN ACCORDANCE WITH THE GOVERNING CODES AND THE WORKING DRAWINGS DOES NOT GUARANTEE PROTECTION FROM LOSS OF LIFE OR INJURY OR PROPERTY DAMAGE.

### DRAWING NOTES:

1. NOTES AND DETAILS ON DRAWINGS SHALL TAKE PRECEDENCE OVER THESE GENERAL SPECIFICATIONS. DIMENSIONS FOR CONSTRUCTION SHALL NOT BE SCALED FROM THE DRAWINGS.
2. THE CONTRACTOR/HOMEOWNER SHALL VERIFY ALL DIMENSIONS, ELEVATIONS AND SITE CONDITIONS BEFORE STARTING WORK. WHERE ACTUAL CONDITIONS CONFLICT WITH THE VARIOUS ELEMENTS OF THE WORKING DRAWINGS AND/OR SPECIFICATIONS, DISCREPANCIES OR OMISSIONS SHALL BE REPORTED TO THE ARCHITECT OR ENGINEER OF RECORD PRIOR TO PROCEEDING WITH CONSTRUCTION.
3. THE CONTRACTOR/HOMEOWNER SHALL ALLOW REASONABLE TIME FOR THE ARCHITECT OR ENGINEER OF RECORD TO RESOLVE CONFLICTS AND/OR MAKE REVISIONS TO THE DRAWINGS AND/OR SPECIFICATIONS. REVISIONS TO THE DRAWINGS SHALL BE REVIEWED AND APPROVED BY THE BUILDING OFFICIAL.
4. THE DRAWINGS AND SPECIFICATIONS REPRESENT THE FINISHED STRUCTURE, UNLESS OTHERWISE SHOWN. THEY DO NOT INDICATE THE METHOD OF CONSTRUCTION. THE CONTRACTOR/HOMEOWNER SHALL SUPERVISE AND DIRECT THE WORK AND HE SHALL BE SOLELY RESPONSIBLE FOR ALL CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES AND PROCEDURES.
5. THE STAMPED SET OF DRAWINGS AND SPECIFICATIONS SHALL BE KEPT AT THE JOB SITE AND SHALL BE AVAILABLE TO THE AUTHORIZED REPRESENTATIVES OF THE BUILDING AND SAFETY DEPARTMENT. THERE SHALL BE NO DEVIATION FROM THE APPROVED PLANS AND SPECIFICATIONS WITHOUT AN APPROVED CHANGE ORDER.

### WOOD AND CARPENTRY:

1. LUMBER SHALL BE COAST REGION DOUGLAS FIR-LARCH GRADE WITH A MAXIMUM MOISTURE CONTENT OF 19% AND SHALL CONFORM TO THE FOLLOWING GRADES, U.N.O.
  - BEAMS AND POST SHALL BE OF #1 OR BETTER.
  - JOIST AND RAFTERS SHALL BE OF #1 OR BETTER.
  - FRAMING SUCH, AS STUDS, FURRING AND BLOCKING SHALL BE DF #2 OR BETTER.
  - SILL PLATES BEARING ON CONCRETE OR MASONRY SHALL BE PRESSURE TREATED DF #1.
2. PLYWOOD SHEATHING SHALL BE DOUGLAS FIR PLYWOOD PLIES WITH EXTERIOR GLUE CONFORMING TO THE LATEST PRODUCT STANDARDS (PS1) BY THE U.S. DEPARTMENT OF COMMERCE.
3. CONNECTIONS LISTED IN THE "NAILING SCHEDULE" ARE MINIMUM REQUIREMENTS FOR COMMON WIRE NAILS. WHERE POSSIBLE, NAILS SHALL BE DRIVEN PERPENDICULAR TO THE GRAIN INSTEAD OF TOE NAILS. (CRC, TABLE R602.3 (1))

4. STEEL FASTENERS AND CONNECTORS SHALL BE SIMPSON OR EQUAL. FULL NAILING OR BOLTING SHALL BE USED ON SPECIFIED HARDWARE, U.N.O.
5. MACHINE BOLT HOLES IN WOOD MEMBERS SHALL HAVE A DIAMETER EQUAL TO THE NOMINAL BOLT DIAMETER. LAG BOLTS IN WOOD MEMBERS SHALL BE PRE-DRILLED TO THE LAG- BOLT DIAMETER MINUS 1/8". A STEEL WASHER SHALL BE PROVIDED UNDER ALL BOLT HEADS AND NUTS THAT BEAR UPON WOOD. BOLTS SHALL BE ASTM A-307 OR BETTER.
6. HOLES AND NOTCHES IN WOOD MEMBERS, UNLESS OTHERWISE DETAILED OR APPROVED BY THE ENGINEER, SHALL MEET THE FOLLOWING REQUIREMENTS: HOLES SHALL BE LOCATED ON THE CENTER OF THE MEMBER OR AT LEAST 2" FROM THE TOP OR BOTTOM OF THE MEMBER; THE DIAMETER OF THE HOLE SHALL NOT EXCEED 1/3 THE DEPTH OF THE MEMBER; NOTCHES IN THE TOP OR BOTTOM OF MEMBERS SHALL NOT EXCEED 1/6 THE DEPTH OF THE MEMBER AND SHALL NOT BE LOCATED IN THE MIDDLE THIRD OF THE SPAN; BEAMS OR JOISTS MAY BE NOTCHED AT THE ENDS WHERE THE NOTCH DOES NOT EXCEED 1/4 OF THE BEAM DEPTH.
7. CUTTING AND NOTCHING OF STUDS: STUDS IN EXTERIOR WALLS AND BEARING PARTITIONS MAY BE CUT OR NOTCHED TO A DEPTH NOT EXCEEDING 25% OF ITS WIDTH. CUTTING OR NOTCHING OF STUDS IN NON-BEARING PARTITIONS SHALL NOT EXCEED 40% OF THE WIDTH.
8. BORED HOLES IN STUDS: A HOLE NOT GREATER IN DIAMETER THAN 40% OF STUD WIDTH MAY BE BORED IN ANY WOOD STUD. BORED HOLES NOT GREATER THAN 60% OF THE WIDTH OF THE STUD ARE PERMITTED IN NONBEARING PARTITIONS. IN NO CASE SHALL THE EDGES OF THE BORED HOLE BE NEARER THAN 5/8" TO THE EDGE OF THE STUD. BORED HOLES SHALL NOT BE LOCATED AT THE SAME SECTION OF STUD AS A CUT OR NOTCH.
9. WOOD MEMBERS BOLTED TO CONCRETE SHALL HAVE A MINIMUM OF 2 BOLTS PER MEMBER, WITH AT LEAST ONE BOLT WITHIN 12" FROM EACH MEMBER END. WOOD IN CONTACT WITH CONCRETE SHALL BE PRESSURE TREATED.
10. STUD PARTITION WALLS AND JOISTS CONTAINING PLUMBING, HEATING OR OTHER PIPES SHALL BE FRAMED TO GIVE PROPER CLEARANCE FOR THE PIPING. WHERE A PARTITION CONTAINING SUCH PIPING RUNS PARALLEL TO FLOOR JOISTS, THE JOIST UNDERNEATH SUCH PARTITION SHALL BE DOUBLED AND SPACED TO PERMIT PASSAGE OF SUCH PIPES.
11. ROOF AND FLOOR SHEATHING SHALL BE AS INDICATED ON THE ACCOMPANYING PLANS. STAGGER PANEL END JOINTS. NAILING TO BE INSPECTED BEFORE COVERING.
12. FOUNDATION SILLS SHALL BE PRESSURE TREATED, OR FOUNDATION GRADE REDWOOD.

### WOOD SHEAR WALLS:

1. PLYWOOD SHEATHING SHALL CONSIST OF MINIMUM 4'X 8' PANELS WHEREVER POSSIBLE. THE MINIMUM PANEL WIDTH SHALL BE 24" WITH 2X BLOCKING MEMBERS. STUCCO APPLIED OVER PLYWOOD SHEATHING SHALL HAVE TWO LAYERS OF GRADE "D" PAPER. PLYWOOD PANELS AND FRAMING SHALL BE NAILED WITH COMMON NAILS. A MINIMUM EDGE DISTANCE OF 1/2" SHALL BE PROVIDED FOR BOUNDARY AND EDGE NAILING ON PLYWOOD SHEATHING OR FRAMING.
2. WOOD SILL PLATES SHALL BE CONTINUOUS AND FREE OF CUTS AND NOTCHES. PERFORATIONS SHALL BE LIMITED TO 1 1/2" IN DIAMETER AND SHALL BE LOCATED AS CLOSE TO THE CENTER AS POSSIBLE.
3. FRAMING MEMBERS WITH PLYWOOD SHEATHING ON BOTH SIDES SHALL BE OFF-SET SO THAT THE PANEL JOINTS FOR EACH SIDE ARE ON DIFFERENT FRAMING MEMBERS.
4. FRAMING MEMBERS, INCLUDING BLOCKING, RECEIVING NAILS SPACED AT 3" O.C. OR LESS (6" O.C. OR LESS FOR FRAMING MEMBERS WITH NAILING FROM BOTH SIDES), SHALL BE 3X NOMINAL OR WIDER. NAIL SPACING SHALL BE STAGGERED.
5. HOLD-DOWNS CONNECTORS SHALL BE SIMPSON OR EQUAL INSTALLED ON 4X FRAMING MEMBERS AND SHALL FOLLOW INSTALLATION RECOMMENDATIONS AS SPECIFIED BY MANUFACTURER. BOLTS ON WOOD POST SHALL HAVE A MAXIMUM OVERSIZED HOLE EQUAL TO THE BOLT DIAMETER PLUS 1/16", SHALL BE TIGHT AND VERIFIED BY INSPECTOR JUST PRIOR TO INSTALLATION OF SHEATHING.
6. SQUARE PLATE WASHERS, INSTEAD OF CUT WASHERS, SHALL BE PROVIDED FOR SILL PLATE ANCHOR BOLTS AND FOR WOOD POSTS AT HOLD-DOWN CONNECTORS BOLTS. PLATE WASHER SHALL BE SIMPSON BP WASHERS OR APPROVED PLATES WITH SAME DIMENSIONS.
7. CONTRACTOR/HOMEOWNER SHALL EXERCISE ALL CARE NECESSARY WHEN USING PNEUMATIC NAILING EQUIPMENT TO INSURE THAT THE FACE PLY OF PLYWOOD SHEATHING IS NOT BROKEN BY NAILHEAD PENETRATION. CONTRACTOR/HOMEOWNER SHALL REPLACE ALL SHEATHING WITH MORE THAN 10% OF THE NAIL HEADS IN ANYONE PLYWOOD PANEL PENETRATING THE FACE PLY. PLYWOOD PANELS MAY BE RE-NAILED AS AN ALTERNATE ONLY WHEN APPROVED IN WRITING BY BOTH THE ARCHITECT/ENGINEER AND THE LOCAL AUTHORITY HAVING JURISDICTION.
8. SHEAR WALLS WITH A SHEAR VALUE GREATER THAN 350 POUNDS PER FOOT SHALL USE A MINIMUM OF 3X NOMINAL MEMBERS FOR FOUNDATION SILL PLATES AND FRAMING MEMBERS RECEIVING EDGE NAILING FROM ABUTTING PLYWOOD PANELS.
9. FASTENERS FOR STUCCO SHEAR WALLS SHALL BE 11 GAGE X 1 1/2" GALVANIZED WIRE LATH FURRED. 1/4" STAPLES AND SELF-FURRING LATH ARE NOT PERMITTED.
10. SOLID BLOCKING SHALL BE PROVIDED AT ALL HORIZONTAL JOINTS OCCURRING IN BRACED WALL PANELS.

### CONCRETE:

1. CONCRETE MIXES SHALL BE SUBMITTED TO THE ARCHITECT OR ENGINEER OF RECORD FOR APPROVAL. MATERIAL SHALL BE PROPORTIONED TO PRODUCE CONCRETE WITH THE FOLLOWING MINIMUM COMPRESSIVE STRENGTHS AT 28 DAYS, U.N.O.
  - CONTINUOUS FOOTINGS: 2,500 PSI
  - ISOLATED PADS: 2500 PSI
  - SLAB ON GRADE: 2500 PSINOTE: CONTINUOUS INSPECTION BY A DEPUTY INSPECTOR IS REQUIRED FOR ALL CONCRETE DESIGNED WITH F'C GREATER THAN 2500 PSI
2. NORMAL WEIGHT CONCRETE SHALL BE 145 TO 155 POUNDS PER CUBIC FOOT. LIGHTWEIGHT CONCRETE SHALL BE IN ACCORDANCE WITH THE APPROVED DESIGN MIX SHOWN ON THE PLANS.

3. CEMENT SHALL CONFORM TO ASTM C 150, TYPE V CEMENT. FINE AND COARSE AGGREGATE SHALL CONFORM TO ASTM C33. WHEN SPECIFIED, AIR-ENTRAINING ADMIXTURES SHALL COMPLY WITH ASTM C260. READY MIX CONCRETE SHALL BE MIXED AND DELIVERED IN ACCORDANCE WITH ASTM C94.
4. MAXIMUM SIZE OF COURSE AGGREGATE FOR SLABS SHALL BE 1" AND 1 1/2" ELSEWHERE, U.N.O. SAND SHALL BE CLEAN, HARD, DURABLE, WASHED, AND FREE FROM SILT, LIME OR CLAY MIXING WATER SHALL BE CLEAN AND FREE FROM INJURIOUS AMOUNTS OF OIL, ACIDS, ALKALIS, ORGANIC MATERIALS OR OTHER DELETERIOUS SUBSTANCES. CONCRETE MIX MAY CONTAIN A POLYMER BASED WATER REDUCING ADMIXTURE. THE MAXIMUM SLUMP OF CONCRETE SHALL NOT EXCEED 6" UNLESS OTHERWISE APPROVED BY THE ARCHITECT OR ENGINEER.
5. CEMENT TYPES SHALL NOT BE MIXED IN THE CONCRETE MIX. CALCIUM CHLORIDE OR FLY ASH SHALL NOT BE USED IN THE CONCRETE MIX.
6. FORMWORK SHALL COMPLY WITH STANDARD PUBLICATION (ACI 347) AND THE PROJECT SPECIFICATIONS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DESIGN, DETAILING, CARE, PLACEMENT AND REMOVAL OF THE FORMWORK AND SHORES.
7. PIPES, DUCTS, SLEEVES, CHASES, ETC. SHALL NOT BE PLACED IN SLABS, BEAMS, OR WALLS UNLESS SPECIFICALLY SHOWN OR NOTED ON PLANS. CONTRACTOR SHALL OBTAIN APPROVAL FOR INSTALLATION OF ANY ADDITIONAL PIPES, DUCTS, ETC. REFER TO ARCHITECTURAL AND MECHANICAL PLANS FOR LOCATIONS OF ALL PIPES, DUCTS, CHASES, ETC. ALL SUSPENDED EQUIPMENT TO BE PROVIDED WITH CRC/CBC APPROVED LATERAL OR SWAYS BRACING.

### EPOXY AND MECHANICAL ANCHORS AND DOWELS:

1. BOLTS AND REINFORCEMENT EMBEDDED INTO CONCRETE OR MASONRY WITH EPOXY SHALL BE INSTALLED PER MANUFACTURER'S RECOMMENDATIONS AND APPROVED ICC-ES/IAPMO-ES EVALUATION REPORTS.
2. MINIMUM SUBSTRATE AND AMBIENT TEMPERATURE SHALL BE AS RECOMMENDED BY MANUFACTURER PRIOR TO PLACING EPOXY. THE MINIMUM AGE OF CONCRETE TO BE BONDED SHALL BE 21 DAYS, U.N.O.
3. THE HOLES SHALL BE DRILLED WITH AN ELECTRO-PNEUMATIC ROTARY HAMMER DRILL USING CARBIDE TIP BITS CONFORMING TO ANSI SPECIFICATION # 894-12-1977. THE HOLES SHALL BE CLEANED OF DUST AND DEBRIS WITH A NYLON BRUSH AND A JET OF COMPRESSED AIR. HOLE DIAMETER AND DEPTH SHALL BE INSTALLED PER MANUFACTURERS RECOMMENDATIONS UNLESS NOTED OTHERWISE.
4. CLEAN MACHINE BOLTS/REINFORCING BARS SHALL BE PLACED IN CLEAN DRILLED HOLES THAT ARE PARTIALLY FILLED WITH EPOXY SO THAT SOME EXCESS EPOXY COMES OUT OF THE HOLE.
5. ALL EPOXY ADHESIVE INSTALLATIONS SHALL HAVE CONTINUOUS SPECIAL INSPECTION PER THE CURRENT CODE REQUIREMENTS AND THE ICC-ES/IAPMO-ES EVALUATION REPORT.

### REINFORCING STEEL:

1. REINFORCING STEEL SHALL CONFORM TO ASTM 615, GRADE 60, U.N.O. STEEL BARS SHALL BE DEFORMED BARS THAT ARE FREE FROM GREASE, RUST, MILL SCALE OR ANY OTHER FOREIGN MATERIAL WHICH MAY AFFECT THE BARS ABILITY TO BOND TO THE CONCRETE. REINFORCING STEEL SHALL HAVE THE MINIMUM PROTECTIVE COVER AS FOLLOWS:

- CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH	3"
- CONCRETE EXPOSED TO EARTH OR WEATHER, # 6 THRU # 11 BARS	2"
- CONCRETE NOT EXPOSED TO WEATHER, NOT IN CONTACT WITH GROUND	1/2"
- CONCRETE FOR SLABS, WALLS AND JOISTS, # 11 BARS AND SMALLER	3/4"
- CONCRETE FOR BEAMS AND COLUMNS, INCLUDING TIES, STIRRUPS, SPIRALS	1 1/2"
- MASONRY WALLS, PILASTER AND LINTELS REINFORCEMENT	1 1/2"
2. ALL DETAILING OF REINFORCING SHALL CONFORM TO THE REQUIREMENTS OF ACI 318, ALL REINFORCING BAR BENDS SHALL BE MADE COLD. REINFORCEMENT THAT IS PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT, U.N.O.
3. CONTRACTOR SHALL USE CHAIRS OR OTHER SUPPORT DEVICES RECOMMENDED BY THE CRSI TO SUPPORT THE REINFORCING BARS OR WELDED WIRE MESH PRIOR TO PLACING CONCRETE. WELDED WIRE MESH SHALL BE CONTINUOUSLY SUPPORTED AT 36" O.C. MAXIMUM.
4. LAP SPLICES SHALL HAVE A MINIMUM LENGTH OF 24" OR 40 BAR DIAMETERS FOR MASONRY AND 12" OR 30 BAR DIAMETERS FOR CONCRETE, U.N.O.
5. REINFORCING STEEL, ANCHOR BOLTS, DOWELS, AND WALL TIES SHALL BE SECURED IN POSITION AND INSPECTED BY THE LOCAL BUILDING INSPECTOR PRIOR TO POURING OF ANY CONCRETE OR GROUTING MASONRY.
6. REINFORCEMENT TO BE WELDED TO STEEL MEMBERS SHALL CONFORM TO ASTM 706 AND SHALL REQUIRE CONTINUOUS INSPECTION.



PROJECT
PROJECT NAME
PROJECT ADDRESS



DISCLAIMER:

BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.


OWNER	
SCALE	
PROJECT NO.	230023
DATE	08-09-2023

STYLE
-------

DESCRIPTION
<b>MINIMUM CONSTRUCTION REQUIREMENTS   GENERAL NOTES</b>


SHEET
<b>S2</b>

TYP. WALL / RAFTER CONNECTION




1

RIDGE DETAIL




2

TYP. PLYWOOD NAILING




3

TYP. SHEAR WALL U.O.N.




4

TYP. HEADER DETAIL




5

TOP PLATE SPLICE DETAIL




6

FOOTING DETAIL




7

FOOTING DETAIL



8

INTERIOR PARTITION WALL TO SLAB



9



PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR: THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.

2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.

3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.

4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.


OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
STRUCTURAL DETAILS


SHEET  
SD1

TYP. REBAR HOOKS, BENDS & SPLICES




10

TYP. SPLICE @ CONC. FTG.




11

DOOR HEAD




12

WINDOW HEAD




13

EAVE AT RAKE VAULTED CEILING




14

DOOR JAMB




15

WINDOW JAMB




16

EAVE AT RAKE W/ CEILING



17

STANDARD WEEP SCREED



18



PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:  
1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.  
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.  
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.  
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.


OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
ARCHITECTURAL DETAILS

SHEET  
SD2

DOOR THRESHOLD




19

WALL PENETRATION FLASHING

NOTES: SECTION 1403.2 C.B.C. CALLS FOR FLASHING OF ALL EXTERIOR OPENINGS EXPOSED TO WEATHER TO MAKE THEM WEATHERPROOF. THIS IS OUR RECOMMENDED PROCEDURE FOR STANDARD FLASHING AT OPENINGS IN WOOD FRAMED EXTERIOR WALLS WHERE THE EXTERIOR WALL FINISH IS APPLIED OVER BUILDING PAPER OR FELT. USE "MOSTOP" FLASHING OR EQUAL WHENEVER POSSIBLE FOR FLASHING MATERIAL. CAULK BACK OF WINDOW FRAMES BEFORE SETTING. USE WINDOWS THAT ARE WATERTIGHT.

THE WIDTH OF FLASHING MATERIAL SHALL PROVIDE FOR A MINIMUM LAP OF 6" AT VERTICAL AND 2" AT HORIZONTAL JOINTS AND OVERLAPS WITH OTHER WEATHER RESISTANT MATERIALS. LINE-WIRE, WHEN USE AS BACKING TO SUPPORT BUILDING PAPER BENEATH WIRE LATH FOR STUCCO, SHOULD BE INSTALLED ACCORDING TO INDUSTRY STANDARDS AND PRACTICE. NO ATTACHMENT DEVICE NOR THE WIRE BACKING SHOULD COVER OR PENETRATE FLASHING MATERIAL. PERIPHERAL FLASHING AT ALL EDGES OF WALL OPENING MUST COVER THE WIRE BACKING.




ATTACH SILL STRIP OF FLASHING MATERIAL AT LEAST 12" WIDE WITH THE TOP EDGE ALIGNED WITH THE TOP EDGE OF THE ROUGH SILL. EXTEND THIS SILL STRIP AT LEAST 14" BEYOND THE EDGE OF THE ROUGH OPENING FOR WINDOW, 2" BEYOND THE JAMB STRIP. ATTACH FLASHING WITH CORROSION RESISTANT NAILS OR RUST-RESISTANT STAPLES. (VERIFY WIDTH OF FLASHING MATERIAL TO ALLOW FOR MINIMUM LAPS AT EXPOSED WOOD TRIM CONDITIONS.)

22

WALL PENETRATION FLASHING


STARTING AT THE BOTTOM OF THE WALL (SOLE PLATE), LAY BUILDING PAPER UNDER THE SILL STRIP. CUT AWAY ANY EXCESS BUILDING PAPER THAT MAY EXTEND ABOVE THE SILL FLANGE ON EACH SIDE OF THE OPENING. APPLY SUCCESSIVE LINES OF BUILDING PAPER OVER JAMB AND HEAD FLANGES, LAPPING EACH COURSE. PAPER SHOULD RUN CONTINUOUSLY OVER HEAD WITH NO SPLICES ABOVE WINDOW.



25

STRAPPING AT OPENING

PROVIDE SHEAR WALL SHEATHING ABOVE AND EACH SIDE BELOW OPENING  
CONTINUOUS CS16 OVER HEADER & SILL AT TOP & BOTTOM OF OPENING, USE 2XFLAT BLOCKING BEHIND WALL SHEATHING




HOLD DOWN, WHERE OCCURS, SEE FOUNDATION PLAN  
EXTEND 24" MIN BEYOND OPENING  
PROVIDE A.B. PER PLAN  
HOLD DOWN, WHERE OCCURS, SEE FOUNDATION PLAN

20


WALL PENETRATION FLASHING

AFTER SILL STRIP IS IN PLACE, ATTACH JAMB STRIP AT LEAST 12" WIDE WITH INSIDE EDGE OF FLASHING ALIGNED WITH EDGE OF WINDOW OPENING. START JAMB STRIPS 2" BELOW THE SILL STRIP AND EXTEND JAMB STRIPS 12" ABOVE THE LOWER EDGE OF THE HEADER, TOP OF WINDOW OPENING. (VERIFY WIDTH OF FLASHING MATERIAL TO ALLOW FOR MINIMUM LAPS AT EXPOSED WOOD TRIM CONDITIONS.)




23

PATIO COVER POST TO FOOTING



26

DOOR THRESHOLD PAN




MARK	POST MIN	NUMBER OF SDS2.5 TO POST	BOLT IN NEW FOOTING	MIN EMBEDMENT
HDU2	(2) 2X	6	SSTB20	17"
HDU4	(2) 2X	10	SSTB24	24"

- NOTE:
1. MINIMUM DISTANCE FROM THE CENTER OF ANCHOR ROD TO THE EDGE OF THE CONCRETE FOOTING SHALL BE 1 3/4"
  2. DEEPEN FOOTINGS AS REQUIRED FOR 3" COVER AT ANCHORS.
  3. MINIMUM EMBEDMENT IS MEASURED FROM TOP OF CONCRETE SLAB
  4. SSTB PROJECTION ABOVE TOP OF CONCRETE SLAB SHALL BE 5"

21


WALL PENETRATION FLASHING

APPLY A CONTINUOUS BEAD OF SEALANT TO THE BACK SURFACE OF THE WINDOW FLANGE. INSTALL WINDOW INTO ROUGH OPENING OVER SILL AND JAMB FLASHING STRIPS PER MANUFACTURER'S REQUIREMENTS. APPLY CONTINUOUS BEAD OF SEALANT TO THE FACE OF THE WINDOW'S TOP FLANGE. ATTACH THE HEAD FLASHING OVER THE WINDOW FLANGE. THIS IS ANOTHER STRIP 12" WIDE WITH A 2" MINIMUM LAP BEYOND THE JAMB STRIPS. (VERIFY WIDTH OF FLASHING MATERIAL TO ALLOW FOR MINIMUM LAPS AT EXPOSED WOOD TRIM CONDITIONS.)



24

POCKET AT RIDGE BEAM / KING POST



27



PROJECT  
PROJECT NAME  
PROJECT ADDRESS



DISCLAIMER:  
BY USING THESE PERMIT READY CONSTRUCTION DOCUMENTS, THE RECIPIENT ACKNOWLEDGES, ACCEPTS AND VOLUNTARILY AFFIRMS THE FOLLOWING CONDITIONS:

1. THE USE OF THIS INFORMATION IS RESTRICTED TO THE ORIGINAL PROJECT FOR WHICH IT WAS PREPARED FOR. THE PERMIT READY ACCESSORY DWELLING UNIT (ADU) PROGRAM FOR THE CITY OF UPLAND ONLY. THIS IS A LIMITED SET OF STANDARDIZED ADU PLANS AND SPECIFICATIONS APPROVED BY THE CITY OF UPLAND BUILDING DEPARTMENT. BUILDING CODES DO CHANGE OVER TIME AND THE RECIPIENT SHALL ENSURE FULL COMPLIANCE UNDER ALL CODES THEN IN EFFECT AT THE TIME OF THE SUBJECT PERMIT. THIS DOES NOT ELIMINATE OR REDUCE THE RECIPIENT'S RESPONSIBILITY TO VERIFY ANY AND ALL INFORMATION RELEVANT TO THE RECIPIENT'S WORK AND RESPONSIBILITY ON THIS PROJECT. LAMFEI LIN BUILDERS SHALL NOT BE RESPONSIBLE FOR TRANSLATION ERRORS. DO NOT USE THESE CONSTRUCTION DOCUMENTS IF THE PERMIT HAS EXPIRED OR IS REVOKED AT ALL.
2. THE RECIPIENT RECOGNIZES AND ACKNOWLEDGES THAT THE USE OF THIS INFORMATION WILL BE AT THEIR SOLE RISK AND WITHOUT ANY LIABILITY OR LEGAL EXPOSURE TO LAMFEI LIN BUILDERS. NO WARRANTIES OF ANY NATURE, WHETHER EXPRESS OR IMPLIED, SHALL BE ATTACHED TO THESE DOCUMENTS AND THE INFORMATION CONTAINED THEREON. ANY USE, REUSE, OR ALTERATION OF THESE DOCUMENTS BY THE RECIPIENT OR BY OTHERS WILL BE AT THE RECIPIENT'S RISK AND FULL LEGAL RESPONSIBILITY. FURTHERMORE, THE RECIPIENT WILL, TO THE FULLEST EXTENT PERMITTED BY LAW, DEFEND, INDEMNIFY, AND HOLD LAMFEI LIN BUILDERS AND ITS ENGINEER HARMLESS FROM ANY AND ALL CLAIMS, SUITS, LIABILITY, DEMANDS, JUDGEMENTS, OR CONDITIONS ARISING OUT OF OR RESULTING THEREFROM ANY USE OF THESE CONSTRUCTION DOCUMENTS FOR OR ON ACCOUNT OF ANY INJURY, DEATH, DAMAGE OR LOSS TO PERSONS OR PROPERTY, INDIRECT OR CONSEQUENTIAL DAMAGES IN ANY AMOUNT. THIS INDEMNITY DOES NOT APPLY TO THE SOLE NEGLIGENCE OR WILLFUL MISCONDUCT OF LAMFEI LIN BUILDERS OR ITS ENGINEER.
3. THE DESIGN REPRESENTED BY THESE PLANS ARE COPYRIGHTED AND ARE SUBJECT TO COPYRIGHT PROTECTION.
4. IF THE RECIPIENT DOES NOT AGREE WITH THE ABOVE CONDITIONS, DO NOT PROCEED WITH THE CONSTRUCTION OF AN ADU OR OTHER IMPROVEMENT UNDER THESE PLANS AT ALL.

OWNER  
SCALE  
PROJECT NO. 230023  
DATE 08-09-2023

STYLE

DESCRIPTION  
ARCHITECTURAL DETAILS

SHEET  
SD3