



GeoTek, Inc.
1548 North Maple Street, Corona, California 92878
(951) 710-1160 Office (951) 710-1167 Fax www.geotekusa.com

MEMO

To: Century Communities
Mr. Brian Taylor

From: GeoTek, Inc
Anna M. Scott

Email: brian@taylor-clark.com **Email:** ascott@geotekusa.com

GeoTek Project No. 4056-CR **Date:** April 25, 2025

Re: APNs 1007-061-008 and -023, 1812 and 1816
West Foothill Boulevard
City of Upland, San Bernardino County, CA

Reference: "Geotechnical and Infiltration Evaluation, Proposed Single-Family Residential Development, Assessor's Parcel Numbers (APNs) 1007-061-08-0000 and 1007-061-23-0000, 1812 and 1816 West Foothill Boulevard, Upland, San Bernardino County, California," by GeoTek, Inc., Project No. 4056-CR, dated February 10, 2025.

As provided in the referenced report (GeoTek, 2025), two (2) infiltration borings were excavated on the project site to evaluate preliminary infiltration rates for the proposed stormwater management facilities. Based on the information obtained and reported (GeoTek, 2025), the preliminary infiltration rates were 3.48 and 4.61 inches per hour at a depth of five (5) feet at the tested locations.

Based on a review of the information provided, an average preliminary infiltration rate of 4 inches per hour may be safely utilized for the design of the proposed stormwater management facilities at the project site.

Bruce A. Hick
GE 2284, Exp. 12/31/26
Geotechnical Engineer

